

Florida Power & Light Company

Business Heating Ventilation & Air Conditioning ("HVAC") Program Tables

Effective: November 2, 2020

FPL Business HVAC Tables

Table of Contents

Disclaimers 2

Chiller Rebate Tables..... 3

DX Rebate Tables 6

ERV Rebate Tables 38

DCV Rebate Tables 40

TES Rebate Tables 42

FPL Business HVAC Tables

Disclaimers

The issuance of a rebate by FPL under the Program shall not be considered or relied upon by the customer to be confirmation that: (i) the customer has selected the proper HVAC system; and/or (ii) that any of the underlying work performed by the Contractor was done properly pursuant to the manufacturer recommendations and specifications, building codes, other applicable laws, industry standards or individual contract requirements. FPL does not participate in or approve the selection of the HVAC system and FPL does not manage or provide oversight of the work performed by the Contractor selected by the customer. It is the sole responsibility of the customer to investigate and select an HVAC system that is appropriate for the specific application, manage the Contractor they select to perform the work and to take the necessary precautions they deem prudent to ensure the equipment and work meets their expectations.

FPL does not provide any supervision, control or instructions to Contractor regarding the means and methods for performing any work that might be eligible for a rebate. This is entirely the responsibility of the Contractor and likewise the sole responsibility of the customer to manage and inspect the work performed by the Contractor.

FPL Business HVAC Tables

Chiller Rebate Tables

Chiller Efficiency Required IPLV ==>		FPL Rebates Air Cooled Chillers Path A		FPL Rebates Air Cooled Chillers Path B	
		Air Cooled with Matching Condenser		Air Cooled with Matching Condenser	
		Tons ≥ 150	Tons < 150	Tons ≥ 150	Tons < 150
		≥ 14.0 IPLV (≤ 0.857 KW/Ton)	≥ 13.700 IPLV (≤ 0.876 KW/Ton)	≥ 16.100 IPLV (≤ 0.745 KW/Ton)	≥ 15.800 IPLV (≤ 0.759 KW/Ton)
EER	KW/TON	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton
15.00	0.80	56.28	56.28	63.38	63.38
14.81	0.81	54.63	54.63	61.93	61.93
14.63	0.82	53.38	53.38	60.48	60.48
14.46	0.83	51.93	51.93	59.03	59.03
14.29	0.84	50.48	50.48	57.58	57.58
14.12	0.85	49.03	49.03	56.13	56.13
13.95	0.86	47.58	47.58	54.68	54.68
13.79	0.87	46.13	46.13	53.23	53.23
13.64	0.88	44.68	44.68	51.78	51.78
13.48	0.89	43.23	43.23	50.33	50.33
13.33	0.90	41.78	41.78	48.88	48.88
13.19	0.91	40.33	40.33	47.43	47.43
13.04	0.92	38.88	38.88	45.98	45.98
12.90	0.93	37.43	37.43	44.53	44.53
12.77	0.94	35.98	35.98	43.08	43.08
12.63	0.95	34.53	34.53	41.63	41.63
12.50	0.96	33.08	33.08	40.18	40.18
12.37	0.97	31.63	31.63	38.73	38.73
12.24	0.98	30.18	30.18	37.28	37.28
12.12	0.99	28.73	28.73	35.83	35.83
12.00	1.00	27.28	27.28	34.38	34.38
11.88	1.01	25.83	25.83	32.93	32.93
11.76	1.02	24.38	24.38	31.48	31.48
11.65	1.03	22.93	22.93	30.03	30.03
11.54	1.04	21.48	21.48	28.58	28.58
11.43	1.05	20.03	20.03	27.13	27.13
11.32	1.06	18.58	18.58	25.68	25.68
11.21	1.07	17.13	17.13	24.23	24.23
11.11	1.08	15.68	15.68	22.78	22.78
11.01	1.09	14.23	14.23	21.33	21.33
10.91	1.10	12.78	12.78	19.88	19.88
10.81	1.11	11.33	11.33	18.43	18.43
10.71	1.12	9.88	9.88	16.98	16.98
10.62	1.13	8.43	8.43	15.53	15.53
10.53	1.14	6.98	6.98	14.08	14.08
10.43	1.15			12.63	12.63
10.34	1.16			11.18	11.18
10.26	1.17			9.73	9.73
10.17	1.18			8.28	8.28
10.08	1.19			6.83	6.83

Notes:

1. Certification required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include kW of chill water pumps
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp, Flow rate 2.4 gpm/ton Air cooled condenser @ ambient air temp 85F
4. Special class/size not AHRI certified must have manufacturer verified specifications at AHRI conditions & approved by FPL HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by FPL
6. Air Cooled chillers without condensers must be rated with matching condensers and comply with the air cooled chiller efficiency requirements

FPL Business HVAC Tables

FPL Rebates Water Cooled Chillers Path A											
KW Reduction Based on ASHRAE 90.1 National Energy Code Minimum Efficiency Standards											
	Water Cooled						Water Cooled				
	Centrifugal						Positive Displacement				
	Tons ≥ 600	400 ≤ Tons < 600	300 ≤ Tons < 400	150 ≤ Tons < 300	Tons < 150		Tons ≥ 600	300 ≤ Tons < 600	150 ≤ Tons < 300	75 ≤ Tons < 150	Tons < 75
Required IPLV ==>	≤ 0.500	≤ 0.500	≤ 0.52	≤ 0.550	≤ 0.550		≤ 0.500	≤ 0.520	≤ 0.54	≤ 0.56	≤ 0.600
Chiller Efficiency	Rebate	Rebate	Rebate	Rebate	Rebate		Rebate	Rebate	Rebate	Rebate	Rebate
EER KW/TON	\$/Ton	\$/Ton	\$/Ton	\$/Ton	\$/Ton		\$/Ton	\$/Ton	\$/Ton	\$/Ton	\$/Ton
26.7	0.45	15.95	15.95	15.95	23.20		15.95	23.20	30.45	39.15	43.50
26.1	0.46	14.50	14.50	14.50	21.75		14.50	21.75	29.00	37.70	42.05
25.5	0.47	13.05	13.05	13.05	20.30		13.05	20.30	27.55	36.25	40.60
25.0	0.48	11.60	11.60	11.60	18.85		11.60	18.85	26.10	34.80	39.15
24.5	0.49	10.15	10.15	10.15	17.40		10.15	17.40	24.65	33.35	37.70
24.0	0.50	8.70	8.70	8.70	15.95		8.70	15.95	23.20	31.90	36.25
23.5	0.51	7.25	7.25	7.25	14.50		7.25	14.50	21.75	30.45	34.80
23.1	0.52	5.80	5.80	5.80	13.05		5.80	13.05	20.30	29.00	33.35
22.6	0.53	4.35	4.35	4.35	11.60		4.35	11.60	18.85	27.55	31.90
22.2	0.54	2.90	2.90	2.90	10.15		2.90	10.15	17.40	26.10	30.45
21.8	0.55				8.70			8.70	15.95	24.65	29.00
21.4	0.56				7.25			7.25	14.50	23.20	27.55
21.1	0.57				5.80			5.80	13.05	21.75	26.10
20.7	0.58				4.35			4.35	11.60	20.30	24.65
20.3	0.59				2.90			2.90	10.15	18.85	23.20
20.0	0.60								8.70	17.40	21.75
19.7	0.61								7.25	15.95	20.30
19.4	0.62								5.80	14.50	18.85
19.0	0.63								4.35	13.05	17.40
18.8	0.64									11.60	15.95
18.5	0.65									10.15	14.50
18.2	0.66									8.70	13.05
17.9	0.67									7.25	11.60
17.6	0.68									5.80	10.15
17.4	0.69									4.35	8.70
17.1	0.70										7.25
16.9	0.71										5.80
16.7	0.72										4.35

Notes:

1. Certification - required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include KW of supply air fans,
Chilled water pump, condensing water pump, tower fans or circulating pumps.
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp, flow rate 2.4 gpm/ton
Water cooled - tower temp 85F, flow 3.0 gpm per ton
4. Special class/size not AHRI certified must have manufacturer verified specifications at AHRI conditions
& approved by FPL HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates Water Cooled Chillers Path B											
KW Reduction Based on ASHRAE 90.1 National Energy Code Minimum Efficiency Standards											
		Water Cooled Centrifugal					Water Cooled Positive Displacement				
		Tons ≥ 600	400 ≤ Tons < 600	300 ≤ Tons < 400	150 ≤ Tons < 300	Tons < 150	Tons ≥ 600	300 ≤ Tons < 600	150 ≤ Tons < 300	75 ≤ Tons < 150	Tons < 75
		≤ 0.380	≤ 0.380	≤ 0.39	≤ 0.400	≤ 0.440	≤ 0.380	≤ 0.410	≤ 0.44	≤ 0.49	≤ 0.500
Required IPLV ==>	Chiller Efficiency	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton	Rebate \$/Ton
EER	KW/TON										
26.7	0.45	19.58	19.58	21.03	26.53	36.53	19.58	25.38	33.35	43.50	47.55
26.1	0.46	18.13	18.13	19.58	25.38	34.08	18.13	23.50	31.90	42.05	46.40
25.5	0.47	16.68	16.68	18.13	23.93	32.63	16.68	22.48	30.45	40.60	44.95
25.0	0.48	15.23	15.23	16.68	22.48	31.18	15.23	21.03	29.00	39.15	43.50
24.5	0.49	13.78	13.78	15.23	21.03	29.73	13.78	19.58	27.55	37.70	42.05
24.0	0.50	12.33	12.33	13.78	19.58	28.28	12.33	18.13	26.10	36.25	40.60
23.5	0.51	10.88	10.88	12.33	18.13	26.83	10.88	16.68	24.65	34.80	39.15
23.1	0.52	9.42	9.42	10.88	16.68	25.38	9.42	15.23	23.20	33.35	37.70
22.6	0.53	7.97	7.97	9.42	15.23	23.93	7.97	13.78	21.75	31.90	36.25
22.2	0.54	6.52	6.52	7.97	13.78	22.48	6.52	12.33	20.30	30.45	34.80
21.8	0.55	5.07	5.07	6.52	12.33	21.03	5.07	10.88	18.85	29.00	33.35
21.4	0.56	3.62	3.62	5.07	10.88	19.58	3.62	9.42	17.40	27.55	31.90
21.1	0.57			3.62	9.42	18.13		7.97	15.95	26.10	30.45
20.7	0.58				7.97	16.68		6.52	14.50	24.65	29.00
20.3	0.59				6.52	15.23		5.07	13.05	23.20	27.55
20.0	0.60				5.07	13.78		3.62	11.60	21.75	26.10
19.7	0.61				3.62	12.33			10.15	20.30	24.65
19.4	0.62					10.88			8.70	18.85	23.20
19.0	0.63					9.42			7.25	17.40	21.75
18.8	0.64					7.97			5.80	15.95	20.30
18.5	0.65					6.52			4.35	14.50	18.85
18.2	0.66					5.07				13.05	17.40
17.9	0.67					3.62				11.60	15.95
17.6	0.68									10.15	14.50
17.4	0.69									8.70	13.05
17.1	0.70									7.25	11.60
16.9	0.71									5.80	10.15
16.7	0.72									4.35	8.70
16.4	0.73										7.25
16.2	0.74										5.80
16.0	0.75										4.35

Notes:

1. Certification required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include KW of supply air fans, Chilled water pump, condensing water pump, tower fans or circulating pumps.
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp, flow rate 2.4 gpm/ton Water cooled - tower temp 85F, flow 3.0 gpm per ton
4. Special class/size not AHRI certified must have manufacturer verified specifications at ARI conditions & approved by FPL HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

DX Rebate Tables

FPL Business HVAC Tables

FPL Rebates Dx Air Conditioners & Condensing Units - Air Cooled - Electric Resistance Heating or No Heating								
Dx Unitary	AHRI 340/360				AHRI 240/210	AHRI 240/210		AHRI 365
	Split System & Single Package				Split System & Single Package	Space Constrained, Air Cooled	Small Duct, High Velocity, Air Cooled	Condensing Units
	Cap Tons Cap MBtuh	Tons ≥ 65.33 MBtuh ≥ 760	20 ≤ Tons < 63.33 240 ≤ MBtuh < 760	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons ≤ 2.5 MBtuh ≤ 30	Tons < 5.42 MBtuh < 65
Eff (S)EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	6.49	6.04	4.71	4.47	2.83	4.76	4.39	5.34
16.0	5.95	5.50	4.17	3.93	2.17	4.11	3.73	4.80
15.0	5.34	4.89	3.56	3.32	1.42	3.36	2.99	4.19
14.9	5.28	4.83	3.49	3.26	1.35	3.29	2.90	4.13
14.8	5.21	4.76	3.42	3.18	1.26	3.20	2.82	4.06
14.7	5.15	4.69	3.36	3.12	1.19	3.13	2.74	4.00
14.6	5.07	4.62	3.29	3.05	1.10	3.04	2.66	3.92
14.5	5.00	4.55	3.21	2.98	1.01	2.95	2.56	3.85
14.4	4.94	4.49	3.15	2.91	0.93	2.87	2.49	3.79
14.3	4.87	4.41	3.08	2.84	0.84	2.78	2.41	3.71
14.2	4.79	4.34	3.01	2.77		2.69	2.31	3.64
14.1	4.72	4.27	2.93	2.69		2.60	2.23	3.57
14.0	4.65	4.19	2.86	2.62		2.51	2.13	3.49
13.9	4.57	4.12	2.79	2.55		2.42	2.05	3.42
13.8	4.49	4.03	2.70	2.46		2.32	1.93	3.34
13.7	4.41	3.96	2.63	2.39		2.23	1.85	3.26
13.6	4.34	3.89	2.55	2.32		2.14	1.77	3.19
13.5	4.26	3.80	2.47	2.23		2.04	1.65	3.10
13.4	4.17	3.72	2.38	2.14		1.93	1.55	3.02
13.3	4.10	3.64	2.31	2.07		1.84	1.47	2.94
13.2	4.01	3.56	2.22	1.99		1.74	1.35	2.86
13.1	3.93	3.47	2.14	1.90		1.63	1.25	2.77
13.0	3.84	3.39	2.05	1.81		1.53	1.16	2.69
12.9	3.75	3.30	1.97	1.73		1.43	1.04	2.60
12.8	3.66	3.20	1.87	1.63		1.31	0.92	2.50
12.7	3.57	3.12	1.78	1.55		1.20		2.42
12.6	3.49	3.03	1.70	1.46		1.10		2.33
12.5	3.39	2.93	1.60	1.36		0.98		2.24
12.4	3.29	2.84	1.50	1.26				2.14
12.3	3.19	2.74	1.40	1.17				2.04
12.2	3.09	2.64	1.31	1.07				1.94
12.1	3.00	2.54	1.21	0.97				1.84
12.0	2.90	2.44	1.11	0.87				1.75
11.9	2.80	2.35	1.01					1.65
11.8	2.69	2.24	0.90					1.54
11.7	2.58	2.13						1.43
11.6	2.48	2.03						1.33
11.5	2.37	1.92						1.22
11.4	2.25	1.80						1.10
11.3	2.14	1.69						0.99
11.2	2.03	1.58						0.88
11.1	1.91	1.45						0.76
11.0	1.79	1.33						0.63
10.9	1.66	1.21						
10.8	1.54	1.09						
10.7	1.42	0.97						
10.6	1.29							
10.5	1.15							
10.4	1.02							

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative
4. All (S)EER's in this table include condensing kW.
5. All (S)EER's on this table include supply fans except for condensing units(AHRI 365)
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Efficiencies higher than maximum table ratings will be computed by FPL.

FPL Business HVAC Tables

FPL Rebates Dx Air Conditioners & Condensing Units - Air Cooled - Non-Electric Resistance Heating						
Dx Unitary	AHRI 340/360				AHRI 240/210	AHRI 365
	Split System & Single Package				Split System & Single Package	Condensing Units
	Cap Tons Cap MBtuh	Tons ≥ 63.33 MBtuh ≥ 760	20 ≤ Tons < 63.33 240 ≤ MBtuh < 760	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
EER (S)EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	6.81	6.34	4.95	4.71	2.32	5.34
16.0	6.27	5.80	4.41	4.17	1.78	4.80
15.0	5.66	5.19	3.80	3.56	1.17	4.19
14.9	5.60	5.13	3.74	3.49	1.11	4.13
14.8	5.53	5.05	3.67	3.42	1.03	4.06
14.7	5.47	4.99	3.61	3.36	0.97	4.00
14.6	5.39	4.92	3.53	3.29	0.90	3.92
14.5	5.32	4.85	3.46	3.21	0.83	3.85
14.4	5.26	4.79	3.40	3.15	0.76	3.79
14.3	5.18	4.71	3.33	3.08	0.69	3.71
14.2	5.11	4.64	3.25	3.01		3.64
14.1	5.04	4.57	3.18	2.93		3.57
14.0	4.96	4.49	3.11	2.86		3.49
13.9	4.89	4.42	3.03	2.79		3.42
13.8	4.81	4.33	2.95	2.70		3.34
13.7	4.73	4.26	2.87	2.63		3.26
13.6	4.66	4.19	2.80	2.55		3.19
13.5	4.57	4.10	2.72	2.47		3.10
13.4	4.49	4.02	2.63	2.38		3.02
13.3	4.41	3.94	2.56	2.31		2.94
13.2	4.33	3.86	2.47	2.22		2.86
13.1	4.24	3.77	2.38	2.14		2.77
13.0	4.16	3.69	2.30	2.05		2.69
12.9	4.07	3.60	2.21	1.97		2.60
12.8	3.97	3.50	2.12	1.87		2.50
12.7	3.89	3.42	2.03	1.78		2.42
12.6	3.80	3.33	1.94	1.70		2.33
12.5	3.71	3.23	1.85	1.60		2.24
12.4	3.61	3.14	1.75	1.50		2.14
12.3	3.51	3.04	1.65	1.40		2.04
12.2	3.41	2.94	1.55	1.31		1.94
12.1	3.31	2.84	1.46	1.21		1.84
12.0	3.22	2.74	1.36	1.11		1.75
11.9	3.12	2.65	1.26	1.01		1.65
11.8	3.01	2.54	1.15	0.90		1.54
11.7	2.90	2.43	1.04			1.43
11.6	2.80	2.33	0.94			1.33
11.5	2.69	2.22				1.22
11.4	2.57	2.10				1.10
11.3	2.46	1.99				0.99
11.2	2.35	1.88				0.88
11.1	2.23	1.75				0.76
11.0	2.10	1.63				0.63
10.9	1.98	1.51				
10.8	1.86	1.39				
10.7	1.74	1.27				
10.6	1.60	1.13				
10.5	1.47	1.00				
10.4	1.33					
10.3	1.20					
10.2	1.07					

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative
4. All (S)EERs in this table include condensing KW.
5. All (S)EERs on this table include supply fans except for condensing units(AHRI 365)
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates Dx Air Conditioners & Condensing Units - Water Cooled - Electric Resistance Heating or No Heating						
Dx Unitary	AHRI 340/360				AHRI 240/210	AHRI 365
	Split System & Single Package				Split System & Single Package	Condensing Units
Cap. Tons Cap MBtuh	Tons ≥ 60.3 MBtuh ≥ 760	60.3 > Tons ≥ 20 760 > MBtuh ≥ 240	11.25 ≤ Tons < 20 136 ≤ MBtuh < 240	6.42 ≤ Tons < 11.25 66 ≤ MBtuh < 136	Tons < 6.42 MBtuh < 66	Tons ≥ 11.25 MBtuh ≥ 136
EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	3.39	3.20	3.10	3.49	3.49	2.24
16.9	3.34	3.15	3.06	3.44	3.44	2.19
16.8	3.30	3.10	3.01	3.39	3.39	2.14
16.7	3.23	3.04	2.95	3.33	3.33	2.08
16.6	3.19	2.99	2.90	3.28	3.28	2.03
16.5	3.14	2.94	2.85	3.24	3.24	1.98
16.4	3.08	2.88	2.79	3.17	3.17	1.92
16.3	3.03	2.83	2.74	3.13	3.13	1.87
16.2	2.97	2.77	2.68	3.06	3.06	1.81
16.1	2.92	2.72	2.63	3.02	3.02	1.76
16.0	2.86	2.66	2.57	2.95	2.95	1.70
15.9	2.79	2.60	2.51	2.89	2.89	1.64
15.8	2.75	2.55	2.46	2.84	2.84	1.59
15.7	2.68	2.49	2.40	2.78	2.78	1.53
15.6	2.62	2.43	2.33	2.72	2.72	1.47
15.5	2.56	2.37	2.27	2.66	2.66	1.40
15.4	2.50	2.31	2.21	2.60	2.60	1.34
15.3	2.44	2.25	2.15	2.54	2.54	1.28
15.2	2.38	2.18	2.09	2.48	2.48	1.22
15.1	2.31	2.11	2.02	2.40	2.40	1.15
15.0	2.24	2.05	1.96	2.34	2.34	1.09
14.9	2.18	1.99	1.89	2.28	2.28	1.03
14.8	2.11	1.92	1.82	2.21	2.21	0.95
14.7	2.05	1.85	1.76	2.15	2.15	0.89
14.6	1.98	1.78	1.69	2.07	2.07	0.82
14.5	1.90	1.71	1.61	2.00	2.00	0.74
14.4	1.84	1.65	1.55	1.94	1.94	0.68
14.3	1.77	1.57	1.48	1.87	1.87	
14.2	1.69	1.50	1.41	1.79	1.79	
14.1	1.62	1.43	1.33	1.72	1.72	
14.0	1.55	1.35	1.26	1.65	1.65	
13.9	1.47	1.28	1.19	1.57	1.57	
13.8	1.39	1.19	1.10	1.49	1.49	
13.7	1.32	1.12	1.03	1.41	1.41	
13.6	1.24	1.05	0.95	1.34	1.34	
13.5	1.16	0.96	0.87	1.26	1.26	
13.4	1.07	0.88	0.78	1.17	1.17	
13.3	1.00	0.80		1.10	1.10	
13.2	0.91			1.01	1.01	
13.1	0.83			0.93	0.93	
13.0				0.84	0.84	
12.9				0.75	0.75	
12.8						
12.7						

- Notes
1. One Ton = 12 MBtuh
 2. Must be AHRI certified where certification is available (250 MBtuh or less).
 3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative.
 4. All (S)EER's in thisTable include supply fans except for condensing units(AHRI 365)
 5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
 6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
 7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
 8. Efficiencies higher than maximum table ratings will be computed by FPL.

FPL Business HVAC Tables

FPL Rebates Dx Air Conditioners & Condensing Units - Water Cooled - Non-Electric Resistance Heating						
Dx Unitary	AHRI 340/360				AHRI 210/240	AHRI 365
	Split System & Single Package				Split System & Single Package	Condensing Units
	Cap Tons Cap MBtuh	Tons ≥ 63.3 MBtuh ≥ 760	63.3 > Tons ≥ 20 760 > MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
Eff EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	3.59	3.39	3.30	3.70	3.49	2.24
16.9	3.54	3.34	3.25	3.65	3.44	2.19
16.8	3.50	3.30	3.20	3.60	3.39	2.14
16.7	3.43	3.23	3.14	3.54	3.33	2.08
16.6	3.39	3.19	3.09	3.49	3.28	2.03
16.5	3.34	3.14	3.04	3.44	3.24	1.98
16.4	3.28	3.08	2.98	3.38	3.17	1.92
16.3	3.23	3.03	2.93	3.33	3.13	1.87
16.2	3.17	2.97	2.87	3.27	3.06	1.81
16.1	3.12	2.92	2.82	3.22	3.02	1.76
16.0	3.06	2.86	2.76	3.16	2.95	1.70
15.9	2.99	2.79	2.70	3.10	2.89	1.64
15.8	2.95	2.75	2.65	3.05	2.84	1.59
15.7	2.88	2.68	2.59	2.99	2.78	1.53
15.6	2.82	2.62	2.53	2.93	2.72	1.47
15.5	2.76	2.56	2.46	2.87	2.66	1.40
15.4	2.70	2.50	2.40	2.80	2.60	1.34
15.3	2.64	2.44	2.34	2.74	2.54	1.28
15.2	2.58	2.38	2.28	2.68	2.48	1.22
15.1	2.51	2.31	2.21	2.61	2.40	1.15
15.0	2.44	2.24	2.15	2.55	2.34	1.09
14.9	2.38	2.18	2.09	2.49	2.28	1.03
14.8	2.31	2.11	2.01	2.41	2.21	0.95
14.7	2.25	2.05	1.95	2.35	2.15	0.89
14.6	2.18	1.98	1.88	2.28	2.07	0.82
14.5	2.10	1.90	1.80	2.21	2.00	0.74
14.4	2.04	1.84	1.74	2.14	1.94	0.68
14.3	1.97	1.77	1.67	2.07	1.87	
14.2	1.89	1.69	1.60	2.00	1.79	
14.1	1.82	1.62	1.52	1.92	1.72	
14.0	1.75	1.55	1.45	1.85	1.65	
13.9	1.67	1.47	1.38	1.78	1.57	
13.8	1.59	1.39	1.29	1.69	1.49	
13.7	1.52	1.32	1.22	1.62	1.41	
13.6	1.44	1.24	1.14	1.55	1.34	
13.5	1.36	1.16	1.06	1.46	1.26	
13.4	1.27	1.07	0.97	1.37	1.17	
13.3	1.20	1.00	0.90	1.30	1.10	
13.2	1.11	0.91	0.81	1.22	1.01	
13.1	1.03	0.83		1.13	0.93	
13.0	0.94			1.04	0.84	
12.9	0.86			0.96	0.75	
12.8	0.76			0.86		
12.7				0.78		

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative.
4. All (S)EERs in this Table include supply fans except for condensing units (AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - lower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

Dx Air Conditioners & Condensing Units - Evaporative Cooled - Electric Resistance Heating or No Heating							
Dx Unitary	AHRI 340/360				AHRI 210/240		AHRI 365
	Split System & Single Package				Split System & Single Package		Condensing Units
Cap Tons	Tons ≥ 63.3	63.3 > Tons ≥ 20	11.25 ≤ Tons < 20	5.42 ≤ Tons < 11.25	Tons < 5.42		Tons ≥ 11.25
Cap MBtuh	MBtuh ≥ 760	760 > MBtuh ≥ 240	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	MBtuh < 65		MBtuh ≥ 135
Eff	Rebate	Rebate	Rebate	Rebate	Rebate	Rebate	Rebate
EER	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh
17.0	3.91	3.70	3.59	3.49	3.49	2.24	
16.9	3.86	3.65	3.54	3.44	3.44	2.19	
16.8	3.81	3.60	3.50	3.39	3.39	2.14	
16.7	3.75	3.54	3.43	3.33	3.33	2.08	
16.6	3.70	3.49	3.39	3.28	3.28	2.03	
16.5	3.65	3.44	3.34	3.24	3.24	1.98	
16.4	3.59	3.38	3.28	3.17	3.17	1.92	
16.3	3.54	3.33	3.23	3.13	3.13	1.87	
16.2	3.48	3.27	3.17	3.06	3.06	1.81	
16.1	3.43	3.22	3.12	3.02	3.02	1.76	
16.0	3.37	3.16	3.06	2.95	2.95	1.70	
15.9	3.31	3.10	2.99	2.89	2.89	1.64	
15.8	3.25	3.05	2.95	2.84	2.84	1.59	
15.7	3.20	2.99	2.88	2.78	2.78	1.53	
15.6	3.14	2.93	2.82	2.72	2.72	1.47	
15.5	3.08	2.87	2.76	2.66	2.66	1.40	
15.4	3.01	2.80	2.70	2.60	2.60	1.34	
15.3	2.95	2.74	2.64	2.54	2.54	1.28	
15.2	2.89	2.68	2.58	2.48	2.48	1.22	
15.1	2.82	2.61	2.51	2.40	2.40	1.15	
15.0	2.76	2.55	2.44	2.34	2.34	1.09	
14.9	2.70	2.49	2.38	2.28	2.28	1.03	
14.8	2.62	2.41	2.31	2.21	2.21	0.95	
14.7	2.56	2.35	2.25	2.15	2.15	0.89	
14.6	2.49	2.28	2.18	2.07	2.07	0.82	
14.5	2.42	2.21	2.10	2.00	2.00	0.74	
14.4	2.35	2.14	2.04	1.94	1.94	0.68	
14.3	2.28	2.07	1.97	1.87	1.87		
14.2	2.21	2.00	1.89	1.79	1.79		
14.1	2.13	1.92	1.82	1.72	1.72		
14.0	2.06	1.85	1.75	1.65	1.65		
13.9	1.99	1.78	1.67	1.57	1.57		
13.8	1.90	1.69	1.59	1.49	1.49		
13.7	1.83	1.62	1.52	1.41	1.41		
13.6	1.76	1.55	1.44	1.34	1.34		
13.5	1.67	1.46	1.36	1.25	1.25		
13.4	1.58	1.37	1.27	1.17	1.17		
13.3	1.51	1.30	1.20	1.10	1.10		
13.2	1.43	1.22	1.11	1.01	1.01		
13.1	1.34	1.13	1.03	0.93	0.93		
13.0	1.25	1.04	0.94	0.84	0.84		
12.9	1.17	0.96	0.86	0.75	0.75		
12.8	1.07	0.86	0.76				
12.7	0.99	0.78					
12.6	0.90						
12.5	0.80						

- Notes
1. One Ton = 12 MBtuh
 2. Must be AHRI certified where certification is available (250 MBtuh or less).
 3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative.
 4. All (S)EER's in this table include supply fans except for condensing units (AHRI 365)
 5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
 6. Equipment rating at net capacity with return air: 80F dry bulb and 67F wet bulb.
 7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
 8. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

<i>Dx Air Conditioners & Condensing Units - Evaporative Cooled - Non-Electric Resistance Heating</i>					
Dx Unitary	AHRI 340/360				AHRI 210/240
	Split System & Single Package				Split System & Single Package
Cap Tons	Tons ≥ 63.3	63.3 > Tons ≥ 20	11.25 ≤ Tons < 20	5.42 ≤ Tons < 11.25	Tons < 5.42
Cap MBtuh	MBtuh ≥ 760	760 > MBtuh ≥ 240	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	MBtuh < 65
Eff	Rebate	Rebate	Rebate	Rebate	Rebate
EER	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh
17.0	4.13	3.91	3.80	3.70	3.49
16.9	4.08	3.86	3.75	3.65	3.44
16.8	4.03	3.81	3.70	3.60	3.39
16.7	3.97	3.75	3.64	3.54	3.33
16.6	3.92	3.70	3.59	3.49	3.28
16.5	3.87	3.65	3.54	3.44	3.24
16.4	3.81	3.59	3.48	3.38	3.17
16.3	3.76	3.54	3.43	3.33	3.13
16.2	3.70	3.48	3.37	3.27	3.06
16.1	3.65	3.43	3.32	3.22	3.02
16.0	3.59	3.37	3.26	3.16	2.95
15.9	3.53	3.31	3.20	3.10	2.89
15.8	3.48	3.26	3.15	3.05	2.84
15.7	3.42	3.20	3.09	2.99	2.78
15.6	3.36	3.14	3.03	2.93	2.72
15.5	3.29	3.08	2.97	2.87	2.66
15.4	3.23	3.01	2.91	2.80	2.60
15.3	3.17	2.95	2.85	2.74	2.54
15.2	3.11	2.89	2.79	2.68	2.48
15.1	3.04	2.82	2.71	2.61	2.40
15.0	2.98	2.76	2.65	2.55	2.34
14.9	2.92	2.70	2.59	2.49	2.28
14.8	2.84	2.62	2.52	2.41	2.21
14.7	2.78	2.56	2.46	2.35	2.15
14.6	2.71	2.49	2.38	2.28	2.07
14.5	2.63	2.42	2.31	2.21	2.00
14.4	2.57	2.35	2.25	2.14	1.94
14.3	2.50	2.28	2.18	2.07	1.87
14.2	2.43	2.21	2.10	2.00	1.79
14.1	2.35	2.13	2.03	1.92	1.72
14.0	2.28	2.06	1.96	1.85	1.65
13.9	2.21	1.99	1.88	1.78	1.57
13.8	2.12	1.90	1.80	1.69	1.49
13.7	2.05	1.83	1.72	1.62	1.41
13.6	1.97	1.76	1.65	1.55	1.34
13.5	1.89	1.67	1.56	1.46	1.26
13.4	1.80	1.58	1.48	1.37	1.17
13.3	1.73	1.51	1.41	1.30	1.10
13.2	1.64	1.43	1.32	1.22	1.01
13.1	1.56	1.34	1.23	1.13	0.93
13.0	1.47	1.25	1.15	1.04	0.84
12.9	1.39	1.17	1.06	0.96	0.75
12.8	1.29	1.07	0.97	0.86	
12.7	1.20	0.99	0.88	0.78	
12.6	1.12	0.90	0.79		
12.5	1.02	0.80			
12.4	0.92				
12.3	0.82				

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative.
4. All (S)EERs in this Table include supply fans except for condensing units (AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates Dx Heat Pump - Air Cooled - Cooling Mode - Electric Resistance Heating or No Heating								
Dx Unitary	AHRI 360/340			AHRI 240/210				AHRI 365
	Split System and Single Package			Split System	Single Package	Space Constrained, Air Cooled, SS SP	Small Duct, High Velocity, Air Cooled	Condensing Units
Cap Tons Cap MBtuh	20 ≥ Tons 240 ≥ MBtuh	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons < 5.42 MBtuh < 65	Tons ≤ 2.5 MBtuh ≤ 30	Tons < 5.42 MBtuh < 65	Tons ≥ 11.25 MBtuh ≥ 135
Eff (S)EER(2)	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	6.81	5.21	4.71	1.99	2.83	4.76	4.38	5.35
16.0	6.27	4.67	4.17	1.33	2.17	4.11	3.73	4.80
15.9	6.21	4.61	4.11	1.25	2.09	4.03	3.65	4.74
15.8	6.16	4.56	4.06	1.19	2.04	3.97	3.59	4.69
15.7	6.10	4.50	4.00	1.12	1.96	3.90	3.52	4.64
15.6	6.04	4.44	3.93	1.05	1.89	3.83	3.44	4.57
15.5	5.98	4.38	3.87	0.97	1.81	3.75	3.37	4.50
15.4	5.92	4.32	3.81	0.90	1.74	3.68	3.29	4.46
15.3	5.86	4.25	3.75	0.82	1.66	3.60	3.22	4.39
15.2	5.80	4.19	3.69		1.59	3.53	3.15	4.32
15.1	5.72	4.12	3.62		1.50	3.44	3.06	4.26
15.0	5.66	4.06	3.56		1.42	3.36	2.98	4.19
14.9	5.60	4.00	3.49		1.35	3.29	2.91	4.13
14.8	5.53	3.92	3.42		1.26	3.20	2.82	4.06
14.7	5.47	3.86	3.36		1.19	3.13	2.74	3.99
14.6	5.39	3.79	3.29		1.10	3.04	2.65	3.93
14.5	5.32	3.72	3.21		1.01	2.95	2.56	3.84
14.4	5.26	3.66	3.15		0.93	2.87	2.49	3.80
14.3	5.18	3.58	3.08		0.84	2.78	2.40	3.71
14.2	5.11	3.51	3.01			2.69	2.31	3.65
14.1	5.04	3.44	2.93			2.60	2.22	3.56
14.0	4.96	3.36	2.86			2.51	2.13	3.50
13.9	4.89	3.29	2.79			2.42	2.04	3.42
13.8	4.81	3.20	2.70			2.32	1.94	3.34
13.7	4.73	3.13	2.63			2.23	1.85	3.26
13.6	4.66	3.06	2.56			2.14	1.76	3.19
13.5	4.57	2.97	2.47			2.04	1.65	3.10
13.4	4.49	2.89	2.38			1.93	1.55	3.02
13.3	4.41	2.81	2.31			1.84	1.46	2.94
13.2	4.33	2.73	2.22			1.74	1.36	2.86
13.1	4.24	2.64	2.14			1.63	1.25	2.77
13.0	4.16	2.56	2.05			1.53	1.15	2.69
12.9	4.07	2.47	1.97			1.43	1.04	2.60
12.8	3.97	2.37	1.87			1.31	0.92	2.50
12.7	3.89	2.29	1.78			1.20		2.42
12.6	3.80	2.20	1.70			1.10		2.33
12.5	3.71	2.10	1.60			0.98		2.24
12.4	3.61	2.01	1.50					2.14
12.3	3.51	1.91	1.40					2.04
12.2	3.41	1.81	1.31					1.94
12.1	3.31	1.71	1.21					1.84
12.0	3.22	1.61	1.11					1.75
11.9	3.12	1.52	1.01					1.65
11.8	3.01	1.41	0.90					1.54
11.7	2.90	1.30						1.43
11.6	2.80	1.20						1.33
11.5	2.69	1.09						1.22
11.4	2.57	0.97						1.10
11.3	2.46	0.86						0.99
11.2	2.35							0.88
11.1	2.23							0.76
11.0	2.10							0.63
10.9	1.98							
10.8	1.86							
10.7	1.74							
10.6	1.60							
10.5	1.47							
10.4	1.33							
10.3	1.20							
10.2	1.07							

- Notes
- One Ton = 12 MBtuh
 - Must be AHRI certified where certification is available (250 MBtuh or less).
 - Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative
 - All (S)EER's in this table include condensing kW.
 - All (S)EER's on this table include supply fans except for condensing units(AHRI 365)
 - Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
 - Efficiencies higher than maximum table ratings will be computed by FPL
 - SS: Split System; SP: Single Package

FPL Business HVAC Tables

FPL Rebates Dx Heat Pump - Air Cooled - Cooling Mode - Non-Electric Resistance Heating								
Dx Unitary	AHRI 360/340			AHRI 240/210				AHRI 365
	Split System and Single Package			Split System	Single Package	Space Constrained, Air Cooled, SS SP	Small Duct, High Velocity, Air Cooled	Condensing Units
	Cap Tons Cap MBtuh	20 ≥ Tons 240 ≥ MBtuh	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons < 5.42 MBtuh < 65	Tons ≤ 2.5 MBtuh ≤ 30	Tons < 5.42 MBtuh < 65
Eff EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
17.0	7.14	5.47	4.95	1.99	2.83	4.76	4.38	5.34
16.0	6.60	4.94	4.41	1.33	2.17	4.11	3.73	4.80
15.9	6.54	4.88	4.35	1.25	2.09	4.03	3.65	4.74
15.8	6.49	4.83	4.30	1.19	2.04	3.97	3.59	4.69
15.7	6.43	4.77	4.24	1.12	1.96	3.90	3.52	4.63
15.6	6.37	4.70	4.18	1.05	1.89	3.83	3.44	4.57
15.5	6.31	4.64	4.12	0.97	1.81	3.75	3.37	4.51
15.4	6.25	4.58	4.06	0.90	1.74	3.68	3.29	4.46
15.3	6.19	4.52	4.00	0.82	1.66	3.60	3.22	4.39
15.2	6.13	4.46	3.94		1.59	3.53	3.15	4.33
15.1	6.06	4.39	3.86		1.50	3.44	3.06	4.26
15.0	5.99	4.33	3.80		1.42	3.36	2.98	4.19
14.9	5.93	4.26	3.74		1.35	3.29	2.91	4.13
14.8	5.86	4.19	3.67		1.26	3.20	2.82	4.06
14.7	5.80	4.13	3.61		1.19	3.13	2.74	4.00
14.6	5.72	4.06	3.53		1.10	3.04	2.65	3.92
14.5	5.65	3.98	3.46		1.01	2.96	2.56	3.85
14.4	5.59	3.92	3.40		0.93	2.87	2.49	3.79
14.3	5.52	3.85	3.33		0.84	2.78	2.40	3.71
14.2	5.44	3.78	3.25			2.69	2.31	3.64
14.1	5.37	3.70	3.18			2.60	2.22	3.57
14.0	5.30	3.63	3.11			2.51	2.13	3.49
13.9	5.22	3.56	3.03			2.42	2.04	3.42
13.8	5.14	3.47	2.95			2.32	1.94	3.34
13.7	5.06	3.40	2.87			2.23	1.85	3.26
13.6	4.99	3.32	2.80			2.14	1.76	3.19
13.5	4.91	3.24	2.72			2.04	1.65	3.10
13.4	4.82	3.15	2.63			1.93	1.55	3.02
13.3	4.75	3.08	2.56			1.84	1.46	2.94
13.2	4.66	2.99	2.47			1.74	1.36	2.86
13.1	4.58	2.91	2.39			1.63	1.25	2.77
13.0	4.49	2.82	2.30			1.53	1.15	2.69
12.9	4.40	2.74	2.21			1.43	1.04	2.60
12.8	4.31	2.64	2.12			1.31	0.92	2.50
12.7	4.22	2.55	2.03			1.20		2.42
12.6	4.14	2.47	1.94			1.10		2.33
12.5	4.04	2.37	1.85			0.98		2.24
12.4	3.94	2.27	1.75					2.14
12.3	3.84	2.17	1.65					2.04
12.2	3.74	2.08	1.55					1.94
12.1	3.65	1.98	1.46					1.84
12.0	3.55	1.88	1.36					1.75
11.9	3.45	1.78	1.26					1.65
11.8	3.34	1.67	1.15					1.54
11.7	3.23	1.56	1.04					1.43
11.6	3.13	1.46	0.94					1.33
11.5	3.02	1.35						1.22
11.4	2.90	1.23						1.10
11.3	2.79	1.12						0.99
11.2	2.68	1.01						0.88
11.1	2.56	0.89						0.76
11.0	2.44							0.63
10.9	2.31							
10.8	2.19							
10.7	2.07							
10.6	1.94							
10.5	1.80							
10.4	1.67							
10.3	1.53							
10.2	1.40							
10.1	1.25							
10.0	1.10							

- Notes:
1. One Ton = 12 MBtuh
 2. Must be AHRI certified where certification is available (250 MBtuh or less).
 3. Special class units not AHRI certified must be approved by FPL HVAC specialist or contractor representative
 4. All (S)EER's in this table include condensing kW.
 5. All (S)EER's on this table include supply fans except for condensing units(AHRI 365)
 6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
 7. Efficiencies higher than maximum table ratings will be computed by FPL
 8. SS: Split System; SP: Single Package

FPL Business HVAC Tables

<i>DX Heat Pump Unitary and Applied - Water Source</i>			
	Water to Air, Water Loop	Water to Air, Water Loop	Water to Water, Water Loop
	Water Source (86 F entering water) ISO 13256-1		Water Source (86 F entering water) ISO 13256-2
Cap	135 > MBtuh ≥ 17	MBtuh < 17	All Cap
Eff EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
20.0	3.95	4.69	6.50
19.0	3.56	4.30	6.11
18.0	3.13	3.87	5.68
17.0	2.65	3.39	5.21
16.0	2.12	2.86	4.67
15.9	2.05	2.79	4.61
15.8	2.01	2.75	4.56
15.7	1.94	2.68	4.50
15.6	1.88	2.62	4.44
15.5	1.82	2.56	4.38
15.4	1.76	2.50	4.32
15.3	1.70	2.44	4.25
15.2	1.64	2.38	4.19
15.1	1.57	2.31	4.12
15.0	1.50	2.24	4.06
14.9	1.44	2.18	4.00
14.8	1.37	2.11	3.92
14.7	1.31	2.05	3.86
14.6	1.24	1.98	3.79
14.5	1.16	1.90	3.72
14.4	1.10	1.84	3.66
14.3	1.03	1.77	3.58
14.2	0.95	1.69	3.51
14.1	0.88	1.62	3.44
14.0	0.81	1.55	3.36
13.9	0.73	1.47	3.29
13.8		1.39	3.20
13.7		1.32	3.13
13.6		1.24	3.06
13.5		1.16	2.97
13.4		1.07	2.89
13.3		1.00	2.81
13.2		0.91	2.73
13.1		0.83	2.64
13.0			2.56
12.9			2.47
12.8			2.37
12.7			2.29
12.6			2.20
12.5			2.10
12.4			2.01
12.3			1.91
12.2			1.81
12.1			1.71
12.0			1.61
11.9			1.52
11.8			1.41
11.7			1.30
11.6			1.20
11.5			1.09
11.4			0.97
11.3			0.86

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI/ ISO certified where certification is available (135 MBtuh or less).
3. Special class units not AHRI/ISO certified must be approved by FPL HVAC specialist or contractor representative
4. All EER's on this table include supply fans kw
5. Liquid flow rate per mfr
6. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

Room Packaged Terminal Air Conditioners and Heat Pumps - Air Cooled (Standard Size)									
AHRI 310/380									
Cap	MDtuh ≥ 15	14 ≤ MDtuh < 15	13 ≤ MDtuh < 14	12 ≤ MDtuh < 13	11 ≤ MDtuh < 12	10 ≤ MDtuh < 11	9 ≤ MDtuh < 10	7 ≤ MDtuh < 9	MDtuh < 7
EER	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh	Ratio \$/MDtuh
14.0	4.96	4.49	4.05	3.63	3.23	2.86	2.51	2.17	1.85
13.9	4.89	4.42	3.97	3.56	3.16	2.79	2.43	2.10	1.78
13.8	4.81	4.33	3.89	3.47	3.07	2.70	2.35	2.01	1.69
13.7	4.73	4.26	3.82	3.40	3.00	2.63	2.27	1.94	1.62
13.6	4.66	4.19	3.74	3.32	2.93	2.55	2.20	1.86	1.55
13.5	4.57	4.10	3.66	3.24	2.84	2.47	2.11	1.78	1.46
13.4	4.49	4.02	3.57	3.15	2.76	2.38	2.03	1.69	1.37
13.3	4.41	3.94	3.50	3.08	2.68	2.31	1.96	1.62	1.30
13.2	4.33	3.86	3.41	2.99	2.60	2.22	1.87	1.53	1.22
13.1	4.24	3.77	3.33	2.91	2.51	2.14	1.78	1.45	1.13
13.0	4.16	3.69	3.24	2.82	2.43	2.05	1.70	1.36	1.04
12.9	4.07	3.60	3.16	2.74	2.34	1.97	1.61	1.28	0.96
12.8	3.97	3.50	3.06	2.64	2.24	1.87	1.52	1.18	0.86
12.7	3.89	3.42	2.97	2.55	2.16	1.78	1.43	1.09	0.78
12.6	3.80	3.33	2.89	2.47	2.07	1.70	1.34	1.01	
12.5	3.71	3.23	2.79	2.37	1.97	1.60	1.25	0.91	
12.4	3.61	3.14	2.69	2.27	1.88	1.50	1.15	0.81	
12.3	3.51	3.04	2.59	2.17	1.78	1.40	1.05		
12.2	3.41	2.94	2.50	2.08	1.68	1.31	0.95		
12.1	3.31	2.84	2.40	1.98	1.58	1.21	0.86		
12.0	3.22	2.74	2.30	1.88	1.49	1.11			
11.9	3.12	2.65	2.20	1.78	1.39	1.01			
11.8	3.01	2.54	2.09	1.67	1.28	0.90			
11.7	2.90	2.43	1.98	1.56	1.17				
11.6	2.80	2.33	1.88	1.46	1.07				
11.5	2.69	2.22	1.77	1.35	0.96				
11.4	2.57	2.10	1.65	1.23	0.84				
11.3	2.46	1.99	1.54	1.12					
11.2	2.35	1.88	1.43	1.01					
11.1	2.23	1.75	1.31	0.89					
11.0	2.10	1.63	1.19						
10.9	1.98	1.51	1.06						
10.8	1.86	1.39	0.94						
10.7	1.74	1.27							
10.6	1.60	1.13							
10.5	1.47	1.00							
10.4	1.33								
10.3	1.20								
10.2	1.07								

Notes

- 1,000 Btuh = 1 MBtuh
- Must be AHRI certified
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

	<i>Single Package Vertical AC and Heat Pumps</i>		
	AHRI 390	AHRI 390	AHRI 390
	Single Pack Vertical AC & HP Single and Three Phase	Single Pack Vertical AC & HP Single and Three Phase	Single Pack Vertical AC & HP Single and Three Phase
Cap	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	65 < Mbtuh
Eff	Rebate	Rebate	Rebate
EER	\$/MBtuh	\$/MBtuh	\$/MBtuh
13.0	3.39	3.39	2.05
12.9	3.30	3.30	1.97
12.8	3.20	3.20	1.87
12.7	3.12	3.12	1.78
12.6	3.03	3.03	1.70
12.5	2.93	2.93	1.60
12.4	2.84	2.84	1.50
12.3	2.74	2.74	1.40
12.2	2.64	2.64	1.31
12.1	2.54	2.54	1.21
12.0	2.44	2.44	1.11
11.9	2.35	2.35	1.01
11.8	2.24	2.24	0.90
11.7	2.13	2.13	
11.6	2.03	2.03	
11.5	1.92	1.92	
11.4	1.80	1.80	
11.3	1.69	1.69	
11.2	1.58	1.58	
11.1	1.45	1.45	
11.0	1.33	1.33	
10.9	1.21	1.21	
10.8	1.09	1.09	
10.7	0.97	0.97	
10.6			

Notes

- 1 1,000 Btuh = 1 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

<i>FPL Rebates DX VRF Air Conditioners - Air Cooled</i>				
Dx Unitary	AHRI 1230			
	Split System & Single Package			
Cap Tons Cap MBtuh	Tons ≥ 20 MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
Eff (S)EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
16.0	5.50	4.17	3.93	2.58
15.0	4.89	3.56	3.32	1.83
14.9	4.83	3.49	3.26	1.76
14.8	4.76	3.42	3.18	1.67
14.7	4.69	3.36	3.12	1.60
14.6	4.62	3.29	3.05	1.51
14.5	4.55	3.21	2.98	1.42
14.4	4.49	3.15	2.91	1.34
14.3	4.41	3.08	2.84	1.25
14.2	4.34	3.01	2.77	1.16
14.1	4.27	2.93	2.69	1.07
14.0	4.19	2.86	2.62	0.99
13.9	4.12	2.79	2.55	0.90
13.8	4.03	2.70	2.46	
13.7	3.96	2.63	2.39	
13.6	3.89	2.55	2.32	
13.5	3.80	2.47	2.23	
13.4	3.72	2.38	2.14	
13.3	3.64	2.31	2.07	
13.2	3.56	2.22	1.99	
13.1	3.47	2.14	1.90	
13.0	3.39	2.05	1.81	
12.9	3.30	1.97	1.73	
12.8	3.21	1.88	1.64	
12.7	3.12	1.78	1.55	
12.6	3.03	1.70	1.46	
12.5	2.93	1.60	1.36	
12.4	2.84	1.50	1.26	
12.3	2.74	1.40	1.17	
12.2	2.64	1.31	1.07	
12.1	2.54	1.21	0.97	
12.0	2.44	1.11	0.87	
11.9	2.35	1.01		
11.8	2.24	0.90		
11.7	2.13			
11.6	2.03			
11.5	1.92			
11.4	1.80			
11.3	1.69			
11.2	1.58			
11.1	1.45			
11.0	1.33			
10.9	1.21			
10.8	1.09			
10.7	0.97			

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX VRF Heat Pumps - Air Cooled							
Dx Unitary	AHRI 1230						
	Multisplit			Multisplit w/Heat Recovery			Condensing Unit
Cap Tons	Tons ≥ 20	11.25 ≤ Tons < 20	5.42 ≤ Tons < 11.25	Tons ≥ 20	11.25 ≤ Tons < 20	5.42 ≤ Tons < 11.25	Tons < 5.42
Cap MBtuh	MBtuh ≥ 240	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	MBtuh ≥ 240	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	MBtuh < 65
Eff (S)EER	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
16.0	6.27	4.67	4.17	6.60	4.93	4.42	2.57
15.0	5.66	4.06	3.56	5.99	4.32	3.81	1.83
14.9	5.59	3.99	3.50	5.94	4.26	3.75	1.77
14.8	5.53	3.93	3.42	5.86	4.19	3.66	1.67
14.7	5.46	3.86	3.37	5.79	4.13	3.61	1.60
14.6	5.40	3.80	3.28	5.73	4.06	3.53	1.50
14.5	5.31	3.71	3.22	5.66	3.98	3.47	1.42
14.4	5.26	3.66	3.15	5.59	3.93	3.40	1.34
14.3	5.18	3.58	3.09	5.51	3.84	3.33	1.25
14.2	5.12	3.51	3.00	5.45	3.78	3.25	1.17
14.1	5.03	3.43	2.94	5.38	3.70	3.18	1.07
14.0	4.97	3.37	2.85	5.30	3.63	3.10	0.99
13.9	4.90	3.28	2.79	5.23	3.56	3.04	0.89
13.8	4.80	3.20	2.71	5.13	3.47	2.95	
13.7	4.74	3.14	2.62	5.07	3.40	2.87	
13.6	4.65	3.05	2.56	5.00	3.32	2.81	
13.5	4.57	2.97	2.48	4.90	3.23	2.72	
13.4	4.49	2.89	2.38	4.82	3.15	2.62	
13.3	4.42	2.81	2.31	4.75	3.09	2.56	
13.2	4.32	2.72	2.23	4.67	2.99	2.48	
13.1	4.24	2.64	2.15	4.57	2.90	2.39	
13.0	4.16	2.56	2.05	4.49	2.82	2.29	
12.9	4.08	2.48	1.96	4.41	2.74	2.21	
12.8	3.99	2.39	1.88	4.32	2.66	2.13	
12.7	3.89	2.29	1.78	4.22	2.56	2.03	
12.6	3.81	2.19	1.70	4.14	2.48	1.95	
12.5	3.71	2.11	1.60	4.04	2.38	1.85	
12.4	3.61	2.01	1.50	3.94	2.28	1.75	
12.3	3.51	1.91	1.40	3.84	2.18	1.65	
12.2	3.42	1.82	1.30	3.75	2.08	1.55	
12.1	3.32	1.72	1.20	3.65	1.98	1.45	
12.0	3.22	1.62	1.11	3.55	1.88	1.35	
11.9	3.12	1.52	1.01	3.45	1.78	1.25	
11.8	3.00	1.40	0.91	3.35	1.67	1.15	
11.7	2.90	1.30		3.23	1.57	1.04	
11.6	2.81	1.20		3.14	1.47	0.94	
11.5	2.69	1.09		3.02	1.35		
11.4	2.57	0.97		2.90	1.24		
11.3	2.46	0.86		2.79	1.12		
11.2	2.34			2.69	1.01		
11.1	2.23			2.56	0.89		
11.0	2.11			2.44			
10.9	1.98			2.31			
10.8	1.86			2.19			
10.7	1.73			2.06			
10.6	1.60			1.93			
10.5	1.47			1.80			
10.4	1.34			1.67			
10.3	1.20			1.53			
10.2	1.07			1.40			
10.1				1.25			
10.0				1.11			

Notes
1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Floor Mounted - Air Cooled							
Dx Unitary	Cap Tons => Cap Mbtuh=>	ANSI / ASHRAE 1360					
		Downflow with or without Economizer			UpFlow - Ducted With or Without Economizer		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80
Sensible Eff EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	6.93	5.38	4.64	7.16	5.58	4.82
12.0	3.517	5.99	4.44	3.70	6.22	4.64	3.88
11.0	3.224	4.88	3.33	2.59	5.12	3.53	2.77
10.9	3.195	4.75	3.20	2.46	5.00	3.40	2.64
10.8	3.165	4.64	3.09	2.34	4.87	3.28	2.52
10.7	3.136	4.52	2.95	2.23	4.75	3.15	2.39
10.6	3.107	4.39	2.82	2.08	4.62	3.02	2.26
10.5	3.077	4.24	2.69	1.95	4.49	2.89	2.13
10.4	3.048	4.11	2.56	1.82	4.34	2.76	2.00
10.3	3.019	3.98	2.43	1.68	4.21	2.62	1.86
10.2	2.989	3.84	2.29	1.55	4.08	2.49	1.73
10.1	2.960	3.70	2.15	1.40	3.93	2.34	1.58
10.0	2.931	3.55	2.00	1.25	3.78	2.19	1.44
9.9	2.902	3.40	1.85	1.11	3.63	2.05	1.29
9.8	2.872	3.25	1.70		3.50	1.90	1.14
9.7	2.843	3.10	1.55		3.33	1.73	0.97
9.6	2.814	2.94	1.39		3.17	1.58	
9.5	2.784	2.77	1.22		3.02	1.42	
9.4	2.755	2.61	1.06		2.84	1.25	
9.3	2.726	2.44			2.69	1.09	
9.2	2.696	2.28			2.51	0.92	
9.1	2.667	2.10			2.33		
9.0	2.638	1.93			2.16		
8.9	2.608	1.73			1.98		
8.8	2.579	1.55			1.78		
8.7	2.550	1.37			1.60		
8.6	2.521	1.17			1.40		
8.5	2.491				1.19		
8.4	2.462						
8.3	2.433						
8.2	2.403						
8.1	2.374						
8.0	2.345						
7.9	2.315						
7.8	2.286						
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Floor Mounted - Air Cooled										
Dx Unitary	Cap Tons ⇨ Cap MBtuh⇨	ANSI / ASHRAE 136B								
		Horizontal With or Without Economizer			UpFlow - NonDucted With Economizer			UpFlow - NonDucted Without Economizer		
		Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh	Rebate \$MBtuh
13.0	3.810	6.12	5.58	4.93	12.47	10.33	9.29	11.47	9.80	8.63
12.0	3.517	5.18	4.64	3.99	11.53	9.37	8.35	10.53	8.86	7.67
11.0	3.224	4.08	3.53	2.89	10.41	8.27	7.23	9.41	7.74	6.57
10.9	3.195	3.94	3.40	2.77	10.30	8.15	7.11	9.29	7.62	6.45
10.8	3.165	3.83	3.28	2.64	10.16	8.02	7.00	9.16	7.49	6.32
10.7	3.136	3.70	3.15	2.52	10.05	7.90	6.86	9.04	7.38	6.20
10.6	3.107	3.56	3.02	2.39	9.92	7.77	6.73	8.91	7.24	6.07
10.5	3.077	3.43	2.89	2.24	9.78	7.64	6.60	8.78	7.11	5.94
10.4	3.048	3.30	2.76	2.11	9.65	7.49	6.47	8.65	6.96	5.79
10.3	3.019	3.17	2.62	1.98	9.50	7.36	6.34	8.50	6.83	5.66
10.2	2.989	3.04	2.49	1.85	9.37	7.23	6.19	8.37	6.70	5.53
10.1	2.960	2.89	2.34	1.70	9.22	7.08	6.06	8.22	6.55	5.38
10.0	2.931	2.74	2.19	1.55	9.08	6.93	5.91	8.09	6.40	5.23
9.9	2.902	2.59	2.05	1.40	8.94	6.78	5.76	7.94	6.25	5.08
9.8	2.872	2.44	1.90	1.25	8.79	6.65	5.61	7.79	6.12	4.95
9.7	2.843	2.28	1.73	1.11	8.63	6.48	5.45	7.62	5.96	4.79
9.6	2.814	2.13	1.58		8.46	6.32	5.30	7.47	5.79	4.62
9.5	2.784	1.96	1.42		8.32	6.17	5.13	7.31	5.64	4.47
9.4	2.755	1.80	1.25		8.13	5.99	4.97	7.14	5.46	4.29
9.3	2.726	1.63	1.09		7.99	5.84	4.80	6.98	5.31	4.14
9.2	2.696	1.47			7.80	5.66	4.64	6.81	5.13	3.96
9.1	2.667	1.29			7.62	5.48	4.46	6.62	4.95	3.78
9.0	2.638	1.11			7.46	5.31	4.27	6.45	4.79	3.61
8.9	2.608				7.28	5.13	4.09	6.27	4.60	3.43
8.8	2.579				7.08	4.93	3.89	6.07	4.41	3.23
8.7	2.550				6.90	4.75	3.71	5.89	4.22	3.05
8.6	2.521				6.70	4.55	3.51	5.69	4.03	2.85
8.5	2.491				6.48	4.34	3.32	5.49	3.81	2.64
8.4	2.462				6.29	4.14	3.10	5.28	3.61	2.44
8.3	2.433				6.07	3.93	2.89	5.07	3.40	2.23
8.2	2.403				5.87	3.71	2.69	4.87	3.20	2.01
8.1	2.374				5.64	3.50	2.48	4.64	2.97	1.80
8.0	2.345				5.41	3.27	2.23	4.41	2.74	1.57
7.9	2.315				5.18	3.04	2.00	4.17	2.51	1.34
7.8	2.286				4.95	2.81	1.77	3.94	2.28	
7.7	2.257				4.70	2.56	1.53	3.70	2.03	
7.6	2.227				4.46	2.31	1.27	3.45	1.78	
7.5	2.198				4.19	2.05		3.18	1.52	
7.4	2.169				3.93	1.78		2.92	1.25	
7.3	2.140				3.66	1.50		2.66		
7.2	2.110				3.38			2.38		
7.1	2.081				3.09			2.10		
7.0	2.052				2.81			1.80		
6.9	2.022				2.49			1.49		
6.8	1.993				2.18					
6.7	1.964				1.86					
6.6	1.934				1.53					
6.5	1.905									

Notes
 1. One Ton = 12 MBtuh
 2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Air Cooled - Free Air discharge Condenser WO Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360 Free Air Discharge Condenser					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	11.10	10.00	9.69	10.87	9.69	9.39
12.0	3.517	10.16	9.06	8.75	9.93	8.75	8.45
11.0	3.224	9.06	7.95	7.64	8.83	7.64	7.33
10.9	3.195	8.93	7.82	7.51	8.70	7.51	7.21
10.8	3.165	8.81	7.71	7.39	8.58	7.39	7.10
10.7	3.136	8.70	7.57	7.26	8.46	7.26	6.96
10.6	3.107	8.55	7.44	7.13	8.33	7.13	6.83
10.5	3.077	8.42	7.31	7.00	8.18	7.00	6.70
10.4	3.048	8.28	7.18	6.86	8.05	6.86	6.57
10.3	3.019	8.15	7.05	6.73	7.92	6.73	6.44
10.2	2.989	8.02	6.91	6.60	7.79	6.60	6.29
10.1	2.960	7.87	6.77	6.45	7.64	6.45	6.15
10.0	2.931	7.72	6.62	6.30	7.49	6.30	6.01
9.9	2.902	7.57	6.47	6.15	7.34	6.15	5.86
9.8	2.872	7.43	6.32	6.01	7.19	6.01	5.71
9.7	2.843	7.28	6.17	5.86	7.05	5.86	5.54
9.6	2.814	7.11	6.01	5.69	6.88	5.69	5.40
9.5	2.784	6.95	5.84	5.53	6.72	5.53	5.23
9.4	2.755	6.78	5.68	5.36	6.55	5.36	5.07
9.3	2.726	6.62	5.51	5.20	6.39	5.20	4.90
9.2	2.696	6.45	5.35	5.03	6.22	5.03	4.74
9.1	2.667	6.27	5.16	4.85	6.04	4.85	4.55
9.0	2.638	6.11	4.98	4.67	5.87	4.67	4.37
8.9	2.608	5.91	4.80	4.49	5.69	4.49	4.19
8.8	2.579	5.73	4.60	4.29	5.49	4.29	3.99
8.7	2.550	5.53	4.42	4.11	5.31	4.11	3.81
8.6	2.521	5.35	4.22	3.91	5.12	3.91	3.61
8.5	2.491	5.13	4.03	3.71	4.90	3.71	3.42
8.4	2.462	4.92	3.81	3.50	4.70	3.50	3.20
8.3	2.433	4.72	3.61	3.30	4.49	3.30	2.99
8.2	2.403	4.50	3.40	3.09	4.27	3.09	2.79
8.1	2.374	4.29	3.18	2.87	4.06	2.87	2.57
8.0	2.345	4.06	2.95	2.64	3.83	2.64	2.33
7.9	2.315	3.83	2.72	2.41	3.60	2.41	2.10
7.8	2.286	3.60	2.49	2.18	3.37	2.18	1.86
7.7	2.257	3.35	2.24	1.93	3.12	1.93	1.62
7.6	2.227	3.09	1.98	1.67	2.85	1.67	1.37
7.5	2.198	2.84	1.73	1.42	2.61	1.42	
7.4	2.169	2.56	1.45		2.34		
7.3	2.140	2.29			2.06		
7.2	2.110	2.01			1.78		
7.1	2.081	1.73			1.50		
7.0	2.052	1.44					
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes
 1. One Ton = 12 MBtuh
 2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Air Cooled - Free Air discharge Condenser W Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	Free Air Discharge Condenser with Fluid Economizer					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	11.72	10.54	10.11	11.47	10.21	9.80
12.0	3.517	10.77	9.60	9.17	10.53	9.27	8.86
11.0	3.224	9.65	8.48	8.05	9.41	8.17	7.74
10.9	3.195	9.54	8.37	7.94	9.29	8.04	7.62
10.8	3.165	9.41	8.25	7.80	9.16	7.92	7.49
10.7	3.136	9.29	8.12	7.69	9.04	7.79	7.38
10.6	3.107	9.16	7.99	7.56	8.91	7.66	7.24
10.5	3.077	9.03	7.85	7.43	8.78	7.52	7.11
10.4	3.048	8.89	7.72	7.28	8.65	7.39	6.96
10.3	3.019	8.75	7.59	7.14	8.50	7.26	6.83
10.2	2.989	8.61	7.44	7.01	8.37	7.13	6.70
10.1	2.960	8.46	7.29	6.86	8.22	6.98	6.55
10.0	2.931	8.32	7.16	6.72	8.09	6.83	6.40
9.9	2.902	8.18	7.01	6.57	7.94	6.68	6.25
9.8	2.872	8.04	6.86	6.44	7.79	6.53	6.12
9.7	2.843	7.87	6.70	6.27	7.62	6.37	5.96
9.6	2.814	7.71	6.55	6.11	7.47	6.22	5.79
9.5	2.784	7.56	6.39	5.96	7.31	6.06	5.64
9.4	2.755	7.38	6.22	5.78	7.14	5.89	5.46
9.3	2.726	7.23	6.06	5.63	6.98	5.73	5.31
9.2	2.696	7.05	5.89	5.45	6.81	5.56	5.13
9.1	2.667	6.86	5.69	5.26	6.62	5.38	4.96
9.0	2.638	6.70	5.53	5.10	6.45	5.20	4.79
8.9	2.608	6.52	5.35	4.92	6.27	5.02	4.60
8.8	2.579	6.32	5.15	4.72	6.07	4.82	4.41
8.7	2.550	6.14	4.97	4.54	5.89	4.64	4.22
8.6	2.521	5.94	4.77	4.34	5.69	4.44	4.03
8.5	2.491	5.73	4.57	4.13	5.49	4.24	3.81
8.4	2.462	5.53	4.36	3.93	5.28	4.03	3.61
8.3	2.433	5.31	4.14	3.71	5.07	3.83	3.40
8.2	2.403	5.12	3.94	3.51	4.87	3.61	3.20
8.1	2.374	4.88	3.71	3.28	4.64	3.40	2.97
8.0	2.345	4.65	3.48	3.05	4.41	3.17	2.74
7.9	2.315	4.42	3.25	2.82	4.17	2.92	2.51
7.8	2.286	4.19	3.02	2.59	3.94	2.69	2.28
7.7	2.257	3.94	2.77	2.34	3.70	2.46	2.03
7.6	2.227	3.70	2.52	2.10	3.45	2.19	1.78
7.5	2.198	3.43	2.26	1.83	3.18	1.93	1.52
7.4	2.169	3.17	2.00	1.57	2.92	1.67	1.25
7.3	2.140	2.90	1.73	1.29	2.66	1.40	
7.2	2.110	2.61	1.45		2.38		
7.1	2.081	2.33			2.10		
7.0	2.052	2.05			1.80		
6.9	2.022	1.73			1.49		
6.8	1.993	1.42					
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Air Cooled - Ducted Condenser WO Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Ducted Condenser					
		Ducted			Nonducted		
Sensible Efficiency EER	Sensible Efficiency SCOP	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
		Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	13.66	12.21	11.83	13.28	11.83	11.47
12.0	3.517	12.62	11.27	10.89	12.34	10.89	10.53
11.0	3.224	11.52	10.16	9.78	11.24	9.78	9.41
10.9	3.195	11.39	10.03	9.65	11.10	9.65	9.29
10.8	3.165	11.27	9.92	9.54	10.99	9.54	9.16
10.7	3.136	11.15	9.78	9.41	10.86	9.41	9.04
10.6	3.107	11.01	9.65	9.27	10.73	9.27	8.91
10.5	3.077	10.87	9.52	9.14	10.59	9.14	8.78
10.4	3.048	10.74	9.39	9.01	10.46	9.01	8.65
10.3	3.019	10.61	9.26	8.88	10.33	8.88	8.50
10.2	2.989	10.48	9.12	8.75	10.20	8.75	8.37
10.1	2.960	10.33	8.98	8.60	10.05	8.60	8.22
10.0	2.931	10.18	8.83	8.45	9.90	8.45	8.09
9.9	2.902	10.03	8.68	8.30	9.75	8.30	7.94
9.8	2.872	9.88	8.53	8.15	9.60	8.15	7.79
9.7	2.843	9.74	8.37	8.00	9.45	8.00	7.62
9.6	2.814	9.57	8.22	7.84	9.29	7.84	7.47
9.5	2.784	9.41	8.06	7.67	9.12	7.67	7.31
9.4	2.755	9.24	7.89	7.51	8.96	7.51	7.14
9.3	2.726	9.08	7.72	7.34	8.79	7.34	6.98
9.2	2.696	8.91	7.56	7.18	8.63	7.18	6.81
9.1	2.667	8.73	7.38	7.00	8.46	7.00	6.62
9.0	2.638	8.56	7.19	6.81	8.27	6.81	6.45
8.9	2.608	8.37	7.01	6.63	8.09	6.63	6.27
8.8	2.579	8.18	6.81	6.44	7.89	6.44	6.07
8.7	2.550	7.99	6.63	6.25	7.71	6.25	5.89
8.6	2.521	7.80	6.44	6.06	7.51	6.06	5.69
8.5	2.491	7.59	6.24	5.86	7.31	5.86	5.49
8.4	2.462	7.38	6.02	5.64	7.10	5.64	5.28
8.3	2.433	7.18	5.82	5.45	6.90	5.45	5.07
8.2	2.403	6.96	5.61	5.23	6.68	5.23	4.87
8.1	2.374	6.75	5.40	5.02	6.47	5.02	4.64
8.0	2.345	6.52	5.16	4.79	6.24	4.79	4.41
7.9	2.315	6.29	4.92	4.55	6.01	4.55	4.17
7.8	2.286	6.06	4.69	4.32	5.78	4.32	3.94
7.7	2.257	5.81	4.46	4.08	5.53	4.08	3.70
7.6	2.227	5.54	4.19	3.81	5.26	3.81	3.45
7.5	2.198	5.30	3.93	3.56	5.02	3.56	3.18
7.4	2.169	5.02	3.66	3.28	4.74	3.28	2.92
7.3	2.140	4.75	3.40	3.02	4.47	3.02	2.66
7.2	2.110	4.47	3.12	2.74	4.19	2.74	2.38
7.1	2.081	4.19	2.84	2.46	3.91	2.46	2.10
7.0	2.052	3.89	2.54	2.16	3.61	2.16	1.80
6.9	2.022	3.60	2.24	1.86	3.32	1.86	1.49
6.8	1.993	3.27	1.91	1.53	2.99	1.53	
6.7	1.964	2.95			2.67		
6.6	1.934	2.62	1.60		2.34		
6.5	1.905	2.28			2.00		
6.4	1.876	1.93			1.65		
6.3	1.846	1.57					
6.2	1.817						
6.1	1.788						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Air Cooled - Ducted Condenser W Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360 - Ducted Condenser with Fluid Economizer					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 66	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 66	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 66	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 66	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	14.31	12.87	12.34	14.01	12.47	11.96
12.0	3.517	13.37	11.93	11.40	13.07	11.53	11.02
11.0	3.224	12.26	10.82	10.28	11.96	10.41	9.90
10.9	3.195	12.13	10.69	10.16	11.83	10.30	9.78
10.8	3.165	12.01	10.58	10.05	11.72	10.16	9.65
10.7	3.136	11.90	10.44	9.92	11.58	10.05	9.54
10.6	3.107	11.75	10.31	9.78	11.45	9.92	9.41
10.5	3.077	11.62	10.18	9.65	11.32	9.78	9.27
10.4	3.048	11.48	10.05	9.52	11.19	9.65	9.14
10.3	3.019	11.35	9.92	9.39	11.06	9.50	8.99
10.2	2.989	11.22	9.78	9.24	10.92	9.37	8.86
10.1	2.960	11.07	9.64	9.11	10.77	9.22	8.71
10.0	2.931	10.92	9.49	8.96	10.63	9.08	8.56
9.9	2.902	10.77	9.34	8.81	10.48	8.94	8.43
9.8	2.872	10.63	9.19	8.66	10.33	8.79	8.28
9.7	2.843	10.48	9.03	8.50	10.16	8.63	8.12
9.6	2.814	10.31	8.88	8.35	10.02	8.46	7.95
9.5	2.784	10.15	8.71	8.18	9.85	8.32	7.80
9.4	2.755	9.98	8.55	8.02	9.69	8.13	7.62
9.3	2.726	9.82	8.38	7.85	9.52	7.99	7.47
9.2	2.696	9.65	8.22	7.69	9.36	7.80	7.29
9.1	2.667	9.47	8.04	7.49	9.17	7.62	7.11
9.0	2.638	9.29	7.85	7.33	8.99	7.46	6.95
8.9	2.608	9.11	7.67	7.14	8.81	7.28	6.77
8.8	2.579	8.91	7.47	6.95	8.61	7.08	6.57
8.7	2.550	8.73	7.29	6.77	8.43	6.90	6.39
8.6	2.521	8.55	7.10	6.57	8.23	6.70	6.19
8.5	2.491	8.33	6.90	6.37	8.04	6.48	5.97
8.4	2.462	8.12	6.68	6.15	7.82	6.29	5.78
8.3	2.433	7.92	6.48	5.94	7.62	6.07	5.56
8.2	2.403	7.71	6.27	5.74	7.41	5.87	5.36
8.1	2.374	7.49	6.06	5.51	7.19	5.64	5.13
8.0	2.345	7.26	5.82	5.28	6.96	5.41	4.90
7.9	2.315	7.03	5.59	5.05	6.72	5.18	4.67
7.8	2.286	6.80	5.36	4.82	6.48	4.95	4.44
7.7	2.257	6.55	5.12	4.57	6.25	4.70	4.19
7.6	2.227	6.29	4.85	4.32	5.99	4.46	3.94
7.5	2.198	6.04	4.60	4.06	5.73	4.19	3.68
7.4	2.169	5.76	4.32	3.80	5.46	3.93	3.42
7.3	2.140	5.49	4.06	3.53	5.20	3.66	3.15
7.2	2.110	5.21	3.78	3.25	4.92	3.38	2.87
7.1	2.081	4.93	3.50	2.97	4.64	3.09	2.57
7.0	2.052	4.64	3.20	2.67	4.34	2.81	2.29
6.9	2.022	4.34	2.90	2.36	4.03	2.49	1.98
6.8	1.993	4.01	2.57	2.05	3.71	2.18	1.67
6.7	1.964	3.70	2.26	1.73	3.40	1.86	1.36
6.6	1.934	3.37	1.93		3.07	1.53	
6.5	1.905	3.02	1.58		2.72		
6.4	1.876	2.67			2.38		
6.3	1.846	2.31			2.01		
6.2	1.817	1.93			1.63		
6.1	1.788	1.55					

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Water Cooled Condenser WO Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=> Sensible Efficiency EER	ANSI / ASHRAE 1360					
		Water Cooled Condenser Condenser					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
		Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.43	7.57	6.78	8.27	7.33	6.55
12.0	3.517	7.49	6.63	5.84	7.33	6.39	5.61
11.0	3.224	6.39	5.53	4.72	6.20	5.28	4.50
10.9	3.195	6.27	5.40	4.60	6.09	5.15	4.39
10.8	3.165	6.14	5.28	4.49	5.96	5.03	4.26
10.7	3.136	6.02	5.15	4.36	5.84	4.90	4.14
10.6	3.107	5.89	5.02	4.22	5.71	4.77	4.01
10.5	3.077	5.74	4.88	4.09	5.58	4.64	3.86
10.4	3.048	5.61	4.75	3.96	5.45	4.50	3.73
10.3	3.019	5.48	4.62	3.83	5.30	4.37	3.60
10.2	2.989	5.35	4.49	3.70	5.16	4.24	3.47
10.1	2.960	5.20	4.34	3.55	5.02	4.09	3.32
10.0	2.931	5.05	4.19	3.40	4.87	3.94	3.17
9.9	2.902	4.90	4.04	3.25	4.74	3.80	3.02
9.8	2.872	4.75	3.89	3.10	4.59	3.65	2.87
9.7	2.843	4.60	3.73	2.94	4.42	3.50	2.72
9.6	2.814	4.44	3.58	2.79	4.26	3.33	2.56
9.5	2.784	4.29	3.42	2.62	4.11	3.17	2.39
9.4	2.755	4.11	3.25	2.46	3.93	3.00	2.23
9.3	2.726	3.96	3.09	2.29	3.78	2.84	2.06
9.2	2.696	3.78	2.92	2.13	3.60	2.67	1.90
9.1	2.667	3.60	2.74	1.95	3.42	2.49	1.72
9.0	2.638	3.43	2.56	1.77	3.25	2.31	1.55
8.9	2.608	3.25	2.38	1.58	3.07	2.13	1.37
8.8	2.579	3.06	2.18	1.39	2.87	1.93	1.17
8.7	2.550	2.87	2.00	1.20	2.69	1.75	
8.6	2.521	2.67	1.80		2.49	1.55	
8.5	2.491	2.46	1.60		2.28	1.35	
8.4	2.462	2.26	1.39		2.08	1.14	
8.3	2.433	2.05	1.19		1.86		
8.2	2.403	1.83			1.67		
8.1	2.374	1.62			1.44		
8.0	2.345	1.39			1.20		
7.9	2.315	1.16					
7.8	2.286						
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

- One Ton = 12 MBtuh
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Water Cooled Condenser W Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Water Cooled Condenser with Fluid Economizer					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.89	8.00	7.16	8.63	7.74	6.93
12.0	3.517	7.95	7.06	6.22	7.67	6.80	5.99
11.0	3.224	6.85	5.94	5.12	6.57	5.69	4.88
10.9	3.195	6.73	5.82	5.00	6.45	5.56	4.75
10.8	3.165	6.60	5.69	4.87	6.32	5.45	4.64
10.7	3.136	6.48	5.58	4.75	6.20	5.31	4.52
10.6	3.107	6.35	5.45	4.62	6.07	5.18	4.39
10.5	3.077	6.20	5.31	4.49	5.94	5.05	4.24
10.4	3.048	6.07	5.16	4.34	5.79	4.92	4.11
10.3	3.019	5.94	5.03	4.21	5.66	4.79	3.98
10.2	2.989	5.81	4.90	4.08	5.53	4.65	3.84
10.1	2.960	5.66	4.75	3.93	5.38	4.50	3.70
10.0	2.931	5.51	4.60	3.78	5.23	4.36	3.55
9.9	2.902	5.36	4.47	3.63	5.08	4.21	3.40
9.8	2.872	5.21	4.32	3.50	4.95	4.06	3.25
9.7	2.843	5.07	4.16	3.33	4.79	3.91	3.10
9.6	2.814	4.90	3.99	3.17	4.62	3.75	2.94
9.5	2.784	4.75	3.84	3.02	4.47	3.58	2.77
9.4	2.755	4.57	3.66	2.84	4.29	3.42	2.61
9.3	2.726	4.42	3.51	2.69	4.14	3.25	2.44
9.2	2.696	4.24	3.33	2.51	3.96	3.09	2.28
9.1	2.667	4.06	3.15	2.33	3.78	2.90	2.10
9.0	2.638	3.89	2.99	2.16	3.61	2.72	1.93
8.9	2.608	3.71	2.81	1.98	3.43	2.54	1.73
8.8	2.579	3.51	2.61	1.78	3.23	2.34	1.55
8.7	2.550	3.33	2.43	1.60	3.05	2.16	1.37
8.6	2.521	3.14	2.23	1.40	2.85	1.96	1.17
8.5	2.491	2.92	2.01	1.19	2.64	1.77	
8.4	2.462	2.72	1.82		2.44	1.55	
8.3	2.433	2.51	1.60		2.23	1.35	
8.2	2.403	2.29	1.40		2.01	1.14	
8.1	2.374	2.08	1.17		1.80		
8.0	2.345	1.85			1.57		
7.9	2.315	1.62			1.34		
7.8	2.286	1.39					
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

- One Ton = 12 MBtuh
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Glycol Cooled Condenser WO Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Glycol Cooled Condenser					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	12.87	10.99	10.54	12.47	10.43	10.21
12.0	3.517	11.93	10.06	9.60	11.53	9.49	9.27
11.0	3.224	10.82	8.94	8.48	10.41	8.38	8.17
10.9	3.195	10.69	8.81	8.37	10.30	8.25	8.04
10.8	3.165	10.58	8.70	8.25	10.16	8.13	7.92
10.7	3.136	10.44	8.58	8.12	10.05	8.00	7.79
10.6	3.107	10.31	8.43	7.99	9.92	7.87	7.66
10.5	3.077	10.18	8.30	7.85	9.78	7.74	7.52
10.4	3.048	10.05	8.17	7.72	9.65	7.61	7.39
10.3	3.019	9.92	8.04	7.59	9.50	7.47	7.26
10.2	2.999	9.78	7.90	7.44	9.37	7.34	7.13
10.1	2.960	9.64	7.76	7.29	9.22	7.19	6.98
10.0	2.931	9.49	7.61	7.16	9.08	7.05	6.83
9.9	2.902	9.34	7.46	7.01	8.94	6.90	6.68
9.8	2.872	9.19	7.31	6.86	8.79	6.75	6.53
9.7	2.843	9.03	7.16	6.70	8.63	6.60	6.37
9.6	2.814	8.88	7.00	6.55	8.46	6.44	6.22
9.5	2.784	8.71	6.83	6.39	8.32	6.27	6.06
9.4	2.755	8.55	6.67	6.22	8.13	6.11	5.89
9.3	2.726	8.38	6.50	6.06	7.99	5.94	5.73
9.2	2.696	8.22	6.34	5.89	7.80	5.78	5.56
9.1	2.667	8.04	6.15	5.69	7.62	5.59	5.38
9.0	2.638	7.86	5.99	5.53	7.46	5.41	5.20
8.9	2.608	7.67	5.79	5.35	7.28	5.23	5.02
8.8	2.579	7.47	5.61	5.15	7.08	5.03	4.82
8.7	2.550	7.29	5.41	4.97	6.90	4.85	4.64
8.6	2.521	7.10	5.23	4.77	6.70	4.65	4.44
8.5	2.491	6.90	5.02	4.57	6.48	4.46	4.24
8.4	2.462	6.68	4.80	4.36	6.29	4.24	4.03
8.3	2.433	6.48	4.60	4.14	6.07	4.04	3.83
8.2	2.403	6.27	4.39	3.94	5.87	3.83	3.61
8.1	2.374	6.06	4.17	3.71	5.64	3.61	3.40
8.0	2.345	5.82	3.94	3.48	5.41	3.38	3.17
7.9	2.315	5.59	3.71	3.25	5.18	3.15	2.92
7.8	2.286	5.36	3.48	3.02	4.95	2.92	2.69
7.7	2.257	5.12	3.23	2.77	4.70	2.67	2.46
7.6	2.227	4.85	2.97	2.52	4.46	2.41	2.19
7.5	2.198	4.60	2.72	2.26	4.19	2.16	1.93
7.4	2.169	4.32	2.44	2.00	3.93	1.88	1.67
7.3	2.140	4.06	2.18	1.73	3.66	1.62	1.40
7.2	2.110	3.78	1.90	1.45	3.38	1.34	
7.1	2.081	3.50	1.62		3.09		
7.0	2.052	3.20	1.32		2.81		
6.9	2.022	2.90			2.49		
6.8	1.993	2.57			2.18		
6.7	1.964				1.86		
6.6	1.934				1.53		
6.5	1.905						

Notes

1. One Ton = 12 MBtuh

2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Ceiling Mounted - Glycol Cooled Condenser W Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360 Glycol Cooled Condenser					
		Ducted			Nonducted		
		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	13.56	11.58	11.10	13.15	10.99	10.77
12.0	3.517	12.62	10.64	10.16	12.21	10.05	9.82
11.0	3.224	11.52	9.54	9.06	11.09	8.94	8.71
10.9	3.195	11.39	9.41	8.93	10.97	8.81	8.60
10.8	3.165	11.27	9.29	8.81	10.84	8.70	8.46
10.7	3.136	11.15	9.16	8.70	10.73	8.58	8.35
10.6	3.107	11.01	9.03	8.55	10.59	8.43	8.22
10.5	3.077	10.87	8.89	8.42	10.46	8.30	8.09
10.4	3.048	10.74	8.76	8.28	10.33	8.17	7.94
10.3	3.019	10.61	8.63	8.15	10.18	8.04	7.80
10.2	2.989	10.48	8.50	8.02	10.05	7.90	7.67
10.1	2.960	10.33	8.35	7.87	9.90	7.76	7.52
10.0	2.931	10.18	8.20	7.72	9.75	7.61	7.38
9.9	2.902	10.03	8.05	7.57	9.62	7.46	7.23
9.8	2.872	9.88	7.90	7.43	9.47	7.31	7.10
9.7	2.843	9.74	7.74	7.28	9.31	7.16	6.93
9.6	2.814	9.57	7.59	7.11	9.14	7.00	6.77
9.5	2.784	9.41	7.43	6.95	8.99	6.83	6.62
9.4	2.755	9.24	7.26	6.78	8.81	6.67	6.44
9.3	2.726	9.08	7.10	6.62	8.66	6.50	6.29
9.2	2.696	8.91	6.93	6.45	8.48	6.34	6.11
9.1	2.667	8.73	6.76	6.27	8.30	6.15	5.92
9.0	2.638	8.56	6.57	6.11	8.13	5.99	5.76
8.9	2.608	8.37	6.39	5.91	7.95	5.79	5.58
8.8	2.579	8.18	6.19	5.73	7.76	5.61	5.38
8.7	2.550	7.99	6.01	5.53	7.57	5.41	5.20
8.6	2.521	7.80	5.81	5.35	7.38	5.23	5.00
8.5	2.491	7.59	5.61	5.13	7.16	5.02	4.79
8.4	2.462	7.38	5.40	4.92	6.96	4.80	4.59
8.3	2.433	7.18	5.20	4.72	6.75	4.60	4.37
8.2	2.403	6.96	4.98	4.50	6.55	4.39	4.16
8.1	2.374	6.75	4.77	4.29	6.32	4.17	3.94
8.0	2.345	6.52	4.54	4.06	6.09	3.94	3.71
7.9	2.315	6.29	4.31	3.83	5.86	3.71	3.48
7.8	2.286	6.06	4.06	3.60	5.63	3.48	3.25
7.7	2.257	5.81	3.83	3.35	5.38	3.23	3.00
7.6	2.227	5.54	3.56	3.09	5.13	2.97	2.76
7.5	2.198	5.30	3.32	2.84	4.87	2.72	2.49
7.4	2.169	5.02	3.04	2.56	4.60	2.44	2.23
7.3	2.140	4.75	2.77	2.29	4.34	2.18	1.95
7.2	2.110	4.47	2.49	2.01	4.06	1.90	1.67
7.1	2.081	4.19	2.21	1.73	3.76	1.62	1.39
7.0	2.052	3.89	1.91	1.44	3.48	1.32	
6.9	2.022	3.60	1.62		3.17		
6.8	1.993	3.27			2.85		
6.7	1.964	2.95			2.54		
6.6	1.934	2.62			2.21		
6.5	1.905	2.28			1.86		
6.4	1.876	1.93			1.50		
6.3	1.846	1.57					

Notes

1. One Ton = 12 MBtuh

2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Water Cooled - Without Economizer							
Dx Unitary	Cap Tons => Cap Mbtuh=>	ANSI / ASHRAE 1360					
		Downflow			Horizontal		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	4.82	4.47	3.96	5.25	4.75	4.13
12.0	3.517	3.88	3.53	3.02	4.31	3.81	3.18
11.9	3.488	3.78	3.43	2.92	4.21	3.73	3.09
11.8	3.458	3.66	3.32	2.82	4.11	3.61	2.99
11.7	3.429	3.56	3.20	2.71	3.99	3.50	2.87
11.6	3.400	3.47	3.10	2.61	3.89	3.40	2.77
11.5	3.370	3.35	3.00	2.49	3.80	3.30	2.66
11.4	3.341	3.23	2.87	2.38	3.66	3.17	2.54
11.3	3.312	3.12	2.77	2.26	3.55	3.07	2.43
11.2	3.283	3.00	2.66	2.16	3.45	2.95	2.33
11.1	3.253	2.89	2.54	2.03	3.32	2.82	2.19
11.0	3.224	2.77	2.41	1.91	3.20	2.71	2.08
10.9	3.195	2.64	2.29	1.78	3.09	2.59	1.95
10.8	3.165	2.52	2.16	1.67	2.95	2.46	1.83
10.7	3.136	2.39	2.05	1.55	2.84	2.34	1.70
10.6	3.107	2.26	1.91	1.40	2.71	2.21	1.57
10.5	3.077	2.13	1.78	1.27	2.56	2.06	1.44
10.4	3.048	2.00	1.65	1.14	2.43	1.93	1.30
10.3	3.019	1.86	1.50	1.01	2.29	1.80	1.17
10.2	2.989	1.73	1.37		2.16	1.67	1.04
10.1	2.960	1.58	1.22		2.01	1.52	
10.0	2.931	1.44	1.07		1.86	1.37	
9.9	2.902	1.29	0.94		1.72	1.22	
9.8	2.872	1.14			1.57	1.07	
9.7	2.843	0.97			1.42		
9.6	2.814				1.25		
9.5	2.784				1.11		
9.4	2.755						
9.3	2.726						
9.2	2.696						
9.1	2.667						
9.0	2.638						
8.9	2.608						
8.8	2.579						
8.7	2.550						
8.6	2.521						
8.5	2.491						
8.4	2.462						
8.3	2.433						
8.2	2.403						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Water Cooled - Without Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Upflow Ducted			Upflow Nonducted		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	5.00	4.64	4.13	8.27	7.24	6.42
12.0	3.517	4.06	3.70	3.18	7.33	6.30	5.46
11.9	3.488	3.96	3.60	3.09	7.23	6.20	5.38
11.8	3.458	3.86	3.50	2.99	7.11	6.11	5.26
11.7	3.429	3.75	3.38	2.87	7.00	5.99	5.15
11.6	3.400	3.65	3.28	2.77	6.90	5.89	5.05
11.5	3.370	3.53	3.17	2.66	6.80	5.78	4.95
11.4	3.341	3.42	3.05	2.54	6.67	5.66	4.82
11.3	3.312	3.30	2.94	2.43	6.57	5.54	4.72
11.2	3.283	3.20	2.84	2.33	6.45	5.45	4.60
11.1	3.253	3.07	2.71	2.19	6.34	5.31	4.47
11.0	3.224	2.95	2.59	2.08	6.20	5.20	4.36
10.9	3.195	2.82	2.46	1.95	6.09	5.07	4.24
10.8	3.165	2.71	2.34	1.83	5.96	4.95	4.11
10.7	3.136	2.57	2.23	1.70	5.84	4.83	3.99
10.6	3.107	2.44	2.08	1.57	5.71	4.69	3.86
10.5	3.077	2.31	1.95	1.44	5.58	4.55	3.73
10.4	3.048	2.18	1.82	1.30	5.45	4.42	3.58
10.3	3.019	2.05	1.68	1.17	5.30	4.29	3.45
10.2	2.989	1.91	1.55	1.04	5.16	4.16	3.32
10.1	2.960	1.77	1.40		5.02	4.01	3.17
10.0	2.931	1.62	1.25		4.87	3.86	3.02
9.9	2.902	1.47	1.11		4.74	3.71	2.87
9.8	2.872	1.32			4.59	3.56	2.74
9.7	2.843	1.17			4.42	3.42	2.57
9.6	2.814	1.01			4.26	3.25	2.41
9.5	2.784				4.11	3.09	2.26
9.4	2.755				3.93	2.92	2.08
9.3	2.726				3.78	2.76	1.93
9.2	2.696				3.60	2.59	1.75
9.1	2.667				3.42	2.41	1.57
9.0	2.638				3.25	2.24	1.40
8.9	2.608				3.07	2.05	1.22
8.8	2.579				2.87	1.86	
8.7	2.550				2.69	1.67	
8.6	2.521				2.49	1.49	
8.5	2.491				2.28	1.27	
8.4	2.462				2.08	1.06	
8.3	2.433				1.86		
8.2	2.403				1.67		
8.1	2.374				1.44		
8.0	2.345				1.20		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Water Cooled - With Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Downflow			Horizontal		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	5.20	4.75	4.24	5.64	5.25	4.59
12.0	3.517	4.26	3.81	3.30	4.70	4.31	3.65
11.9	3.488	4.16	3.73	3.20	4.60	4.21	3.55
11.8	3.458	4.04	3.61	3.09	4.49	4.11	3.43
11.7	3.429	3.93	3.50	2.99	4.39	3.99	3.32
11.6	3.400	3.83	3.40	2.89	4.29	3.89	3.22
11.5	3.370	3.73	3.30	2.77	4.17	3.80	3.12
11.4	3.341	3.60	3.17	2.66	4.06	3.66	2.99
11.3	3.312	3.50	3.07	2.54	3.94	3.55	2.89
11.2	3.283	3.38	2.95	2.43	3.83	3.45	2.77
11.1	3.253	3.27	2.82	2.31	3.71	3.32	2.66
11.0	3.224	3.14	2.71	2.18	3.60	3.20	2.52
10.9	3.195	3.02	2.59	2.06	3.47	3.09	2.41
10.8	3.165	2.89	2.46	1.95	3.35	2.95	2.28
10.7	3.136	2.77	2.34	1.82	3.22	2.84	2.16
10.6	3.107	2.64	2.21	1.68	3.09	2.71	2.03
10.5	3.077	2.51	2.06	1.55	2.95	2.56	1.90
10.4	3.048	2.36	1.93	1.42	2.82	2.43	1.77
10.3	3.019	2.23	1.80	1.29	2.69	2.29	1.62
10.2	2.989	2.10	1.67	1.14	2.56	2.16	1.49
10.1	2.960	1.95	1.52	1.01	2.41	2.01	1.34
10.0	2.931	1.80	1.37		2.26	1.86	1.19
9.9	2.902	1.65	1.22		2.11	1.72	1.06
9.8	2.872	1.52	1.07		1.96	1.57	
9.7	2.843	1.35			1.80	1.42	
9.6	2.814	1.19			1.65	1.25	
9.5	2.784	1.04			1.49	1.11	
9.4	2.755				1.32		
9.3	2.726				1.16		
9.2	2.696						
9.1	2.667						
9.0	2.638						
8.9	2.608						
8.8	2.579						
8.7	2.550						
8.6	2.521						
8.5	2.491						
8.4	2.462						
8.3	2.433						
8.2	2.403						

Notes

- One Ton = 12 MBtuh
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Water Cooled - With Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Upflow Ducted			Upflow Nonducted		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	5.38	4.93	4.41	8.99	7.90	7.01
12.0	3.517	4.44	3.99	3.47	8.05	6.96	6.07
11.9	3.488	4.34	3.89	3.37	7.95	6.86	5.97
11.8	3.458	4.24	3.80	3.27	7.85	6.77	5.86
11.7	3.429	4.13	3.68	3.15	7.74	6.65	5.76
11.6	3.400	4.03	3.58	3.05	7.64	6.55	5.66
11.5	3.370	3.91	3.48	2.94	7.52	6.45	5.54
11.4	3.341	3.80	3.35	2.82	7.41	6.32	5.43
11.3	3.312	3.68	3.23	2.71	7.29	6.20	5.31
11.2	3.283	3.58	3.14	2.61	7.19	6.11	5.20
11.1	3.253	3.45	3.00	2.48	7.06	5.97	5.08
11.0	3.224	3.33	2.89	2.36	6.95	5.86	4.97
10.9	3.195	3.20	2.77	2.23	6.81	5.74	4.83
10.8	3.165	3.09	2.64	2.11	6.70	5.61	4.72
10.7	3.136	2.95	2.52	1.98	6.58	5.49	4.59
10.6	3.107	2.82	2.39	1.85	6.45	5.36	4.46
10.5	3.077	2.69	2.24	1.72	6.30	5.21	4.32
10.4	3.048	2.56	2.11	1.58	6.17	5.08	4.19
10.3	3.019	2.43	1.98	1.45	6.04	4.95	4.06
10.2	2.989	2.29	1.85	1.32	5.91	4.82	3.93
10.1	2.960	2.15	1.70	1.17	5.76	4.67	3.78
10.0	2.931	2.00	1.55	1.02	5.61	4.52	3.63
9.9	2.902	1.85	1.40		5.46	4.37	3.48
9.8	2.872	1.70	1.25		5.31	4.22	3.33
9.7	2.843	1.55	1.11		5.16	4.08	3.17
9.6	2.814	1.39			5.00	3.91	3.02
9.5	2.784	1.22			4.83	3.76	2.85
9.4	2.755	1.06			4.67	3.58	2.69
9.3	2.726				4.50	3.43	2.52
9.2	2.696				4.34	3.25	2.36
9.1	2.667				4.16	3.07	2.18
9.0	2.638				3.99	2.90	2.00
8.9	2.608				3.80	2.72	1.82
8.8	2.579				3.61	2.52	1.62
8.7	2.550				3.43	2.34	1.44
8.6	2.521				3.23	2.15	1.24
8.5	2.491				3.02	1.93	
8.4	2.462				2.81	1.73	
8.3	2.433				2.61	1.52	
8.2	2.403				2.39	1.30	
8.1	2.374				2.18		
8.0	2.345				1.95		
7.9	2.315				1.72		
7.8	2.286				1.49		
7.7	2.257				1.24		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Glycol Cooled - Without Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Downflow			Horizontal		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.17	7.90	5.51	8.43	8.43	6.06
12.0	3.517	7.23	6.96	4.57	7.49	7.49	5.12
11.9	3.488	7.13	6.86	4.47	7.41	7.41	5.02
11.8	3.458	7.03	6.77	4.36	7.29	7.29	4.90
11.7	3.429	6.91	6.65	4.26	7.18	7.18	4.80
11.6	3.400	6.81	6.55	4.16	7.08	7.08	4.70
11.5	3.370	6.70	6.45	4.04	6.98	6.98	4.59
11.4	3.341	6.58	6.32	3.93	6.85	6.85	4.47
11.3	3.312	6.47	6.20	3.81	6.73	6.73	4.36
11.2	3.283	6.37	6.11	3.70	6.63	6.63	4.24
11.1	3.253	6.24	5.97	3.58	6.50	6.50	4.13
11.0	3.224	6.12	5.86	3.47	6.39	6.39	3.99
10.9	3.195	5.99	5.74	3.33	6.27	6.27	3.88
10.8	3.165	5.87	5.61	3.22	6.14	6.14	3.76
10.7	3.136	5.74	5.49	3.09	6.02	6.02	3.63
10.6	3.107	5.61	5.36	2.95	5.89	5.89	3.50
10.5	3.077	5.48	5.21	2.82	5.74	5.74	3.37
10.4	3.048	5.35	5.08	2.69	5.61	5.61	3.23
10.3	3.019	5.21	4.95	2.56	5.48	5.48	3.10
10.2	2.989	5.08	4.82	2.43	5.35	5.35	2.95
10.1	2.960	4.93	4.67	2.28	5.20	5.20	2.82
10.0	2.931	4.79	4.52	2.13	5.05	5.05	2.67
9.9	2.902	4.64	4.37	1.98	4.90	4.90	2.52
9.8	2.872	4.49	4.22	1.83	4.75	4.75	2.38
9.7	2.843	4.34	4.08	1.67	4.60	4.60	2.21
9.6	2.814	4.17	3.91	1.52	4.44	4.44	2.06
9.5	2.784	4.01	3.76	1.35	4.29	4.29	1.90
9.4	2.755	3.84	3.58	1.19	4.11	4.11	1.73
9.3	2.726	3.68	3.43	1.02	3.96	3.96	1.57
9.2	2.696	3.51	3.25		3.78	3.78	1.40
9.1	2.667	3.33	3.07		3.60	3.60	1.20
9.0	2.638	3.15	2.90		3.43	3.43	1.04
8.9	2.608	2.97	2.72		3.25	3.25	
8.8	2.579	2.77	2.52		3.05	3.05	
8.7	2.550	2.59	2.34		2.87	2.87	
8.6	2.521	2.39	2.15		2.67	2.67	
8.5	2.491	2.19	1.93		2.46	2.46	
8.4	2.462	1.98	1.73		2.26	2.26	
8.3	2.433	1.78	1.52		2.05	2.05	
8.2	2.403	1.57	1.30		1.83	1.83	
8.1	2.374	1.35			1.62	1.62	
8.0	2.345	1.12			1.39	1.39	
7.9	2.315				1.16	1.16	
7.8	2.286						
7.7	2.257						

Notes

- One Ton = 12 MBtuh
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Glycol Cooled - Without Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Upflow Ducted			Upflow Nonducted		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.43	8.17	5.71	12.47	11.35	9.39
10.9	3.195	6.27	5.99	3.53	10.30	9.17	7.21
10.8	3.165	6.14	5.87	3.42	10.16	9.04	7.10
10.7	3.136	6.02	5.74	3.28	10.05	8.93	6.96
10.6	3.107	5.89	5.61	3.15	9.92	8.79	6.83
10.5	3.077	5.74	5.48	3.02	9.78	8.66	6.70
10.4	3.048	5.61	5.35	2.89	9.65	8.51	6.57
10.3	3.019	5.48	5.21	2.76	9.50	8.38	6.44
10.2	2.989	5.35	5.08	2.62	9.37	8.25	6.29
10.1	2.960	5.20	4.93	2.48	9.22	8.10	6.15
10.0	2.931	5.05	4.79	2.33	9.08	7.95	6.01
9.9	2.902	4.90	4.64	2.18	8.94	7.80	5.86
9.8	2.872	4.75	4.49	2.03	8.79	7.67	5.71
9.7	2.843	4.60	4.34	1.88	8.63	7.51	5.54
9.6	2.814	4.44	4.17	1.72	8.46	7.34	5.40
9.5	2.784	4.29	4.01	1.55	8.32	7.19	5.23
9.4	2.755	4.11	3.84	1.39	8.13	7.01	5.07
9.3	2.726	3.96	3.68	1.22	7.99	6.86	4.90
9.2	2.696	3.78	3.51	1.06	7.80	6.68	4.74
9.1	2.667	3.60	3.33		7.62	6.50	4.55
9.0	2.638	3.43	3.15		7.46	6.34	4.37
8.9	2.608	3.25	2.97		7.28	6.15	4.19
8.8	2.579	3.05	2.77		7.08	5.96	3.99
8.7	2.550	2.87	2.59		6.90	5.78	3.81
8.6	2.521	2.67	2.39		6.70	5.58	3.61
8.5	2.491	2.46	2.19		6.48	5.36	3.42
8.4	2.462	2.26	1.98		6.29	5.16	3.20
8.3	2.433	2.05	1.78		6.07	4.95	2.99
8.2	2.403	1.83	1.57		5.87	4.74	2.79
8.1	2.374	1.62	1.35		5.64	4.52	2.57
8.0	2.345	1.39	1.12		5.41	4.29	2.33
7.9	2.315	1.16			5.18	4.06	2.10
7.8	2.286				4.95	3.83	1.86
7.7	2.257				4.70	3.58	1.62
7.6	2.227				4.46	3.33	1.37
7.5	2.198				4.19	3.07	
7.4	2.169				3.93	2.81	
7.3	2.140				3.66	2.52	
7.2	2.110				3.38	2.24	
7.1	2.081				3.09	1.96	
7.0	2.052				2.81	1.68	
6.9	2.022				2.49	1.37	
6.8	1.993				2.18		
6.7	1.964				1.86		
6.6	1.934				1.53		
6.5	1.905						

Notes

- One Ton = 12 MBtuh
- Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Glycol Cooled - With Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Downflow			Horizontal		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.71	8.35	5.84	9.19	9.19	6.34
12.0	3.517	7.77	7.41	4.90	8.25	8.25	5.40
11.9	3.488	7.67	7.31	4.80	8.15	8.15	5.30
11.8	3.458	7.56	7.19	4.70	8.04	8.04	5.18
11.7	3.429	7.46	7.10	4.59	7.94	7.94	5.08
11.6	3.400	7.36	7.00	4.49	7.84	7.84	4.98
11.5	3.370	7.24	6.88	4.37	7.72	7.72	4.87
11.4	3.341	7.13	6.77	4.26	7.61	7.61	4.75
11.3	3.312	7.01	6.65	4.14	7.49	7.49	4.64
11.2	3.283	6.90	6.53	4.04	7.38	7.38	4.52
11.1	3.253	6.78	6.42	3.91	7.26	7.26	4.41
11.0	3.224	6.67	6.30	3.80	7.14	7.14	4.29
10.9	3.195	6.53	6.17	3.66	7.01	7.01	4.16
10.8	3.165	6.42	6.06	3.55	6.90	6.90	4.04
10.7	3.136	6.29	5.92	3.43	6.77	6.77	3.91
10.6	3.107	6.15	5.79	3.28	6.63	6.63	3.78
10.5	3.077	6.02	5.66	3.15	6.50	6.50	3.65
10.4	3.048	5.89	5.53	3.02	6.37	6.37	3.51
10.3	3.019	5.76	5.40	2.89	6.24	6.24	3.38
10.2	2.989	5.63	5.26	2.76	6.11	6.11	3.25
10.1	2.960	5.48	5.12	2.61	5.96	5.96	3.10
10.0	2.931	5.33	4.97	2.46	5.81	5.81	2.95
9.9	2.902	5.18	4.82	2.31	5.66	5.66	2.81
9.8	2.872	5.03	4.67	2.16	5.51	5.51	2.66
9.7	2.843	4.87	4.50	2.01	5.35	5.35	2.51
9.6	2.814	4.72	4.36	1.85	5.20	5.20	2.34
9.5	2.784	4.55	4.19	1.68	5.03	5.03	2.18
9.4	2.755	4.39	4.03	1.52	4.87	4.87	2.01
9.3	2.726	4.22	3.86	1.35	4.70	4.70	1.85
9.2	2.696	4.06	3.70	1.19	4.54	4.54	1.68
9.1	2.667	3.88	3.51		4.36	4.36	1.50
9.0	2.638	3.70	3.33		4.17	4.17	1.32
8.9	2.608	3.51	3.15		3.99	3.99	1.14
8.8	2.579	3.32	2.95		3.80	3.80	
8.7	2.550	3.14	2.77		3.61	3.61	
8.6	2.521	2.94	2.57		3.42	3.42	
8.5	2.491	2.74	2.38		3.22	3.22	
8.4	2.462	2.52	2.16		3.00	3.00	
8.3	2.433	2.33	1.96		2.81	2.81	
8.2	2.403	2.11	1.75		2.59	2.59	
8.1	2.374	1.90	1.53		2.38	2.38	
8.0	2.345	1.67	1.30		2.15	2.15	
7.9	2.315	1.44			1.90	1.90	
7.8	2.286	1.19			1.67	1.67	
7.7	2.257				1.44	1.44	

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

FPL Rebates DX Computer Rm - Glycol Cooled - With Fluid Economizer							
Dx Unitary	Cap Tons => Cap MBtuh=>	ANSI / ASHRAE 1360					
		Upflow Ducted			Upflow Nonducted		
		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh	Rebate \$/MBtuh
13.0	3.810	8.99	8.63	6.06	13.56	12.34	10.21
10.9	3.195	6.81	6.45	3.88	11.39	10.16	8.04
10.8	3.165	6.70	6.32	3.76	11.27	10.05	7.92
10.7	3.136	6.58	6.20	3.63	11.15	9.92	7.79
10.6	3.107	6.45	6.07	3.50	11.01	9.78	7.66
10.5	3.077	6.30	5.94	3.37	10.87	9.65	7.52
10.4	3.048	6.17	5.79	3.23	10.74	9.52	7.39
10.3	3.019	6.04	5.66	3.10	10.61	9.39	7.26
10.2	2.989	5.91	5.53	2.95	10.48	9.24	7.13
10.1	2.960	5.76	5.38	2.82	10.33	9.11	6.98
10.0	2.931	5.61	5.23	2.67	10.18	8.96	6.83
9.9	2.902	5.46	5.08	2.52	10.03	8.81	6.68
9.8	2.872	5.31	4.95	2.38	9.88	8.66	6.53
9.7	2.843	5.16	4.79	2.21	9.74	8.50	6.37
9.6	2.814	5.00	4.62	2.06	9.57	8.35	6.22
9.5	2.784	4.83	4.47	1.90	9.41	8.18	6.06
9.4	2.755	4.67	4.29	1.73	9.24	8.02	5.89
9.3	2.726	4.50	4.14	1.57	9.08	7.85	5.73
9.2	2.696	4.34	3.96	1.40	8.91	7.69	5.56
9.1	2.667	4.16	3.78	1.20	8.73	7.49	5.38
9.0	2.638	3.99	3.61	1.04	8.56	7.33	5.20
8.9	2.608	3.80	3.43		8.37	7.14	5.02
8.8	2.579	3.61	3.23		8.18	6.95	4.82
8.7	2.550	3.43	3.05		7.99	6.77	4.64
8.6	2.521	3.23	2.85		7.80	6.57	4.44
8.5	2.491	3.02	2.64		7.59	6.37	4.24
8.4	2.462	2.81	2.44		7.38	6.15	4.03
8.3	2.433	2.61	2.23		7.18	5.94	3.83
8.2	2.403	2.39	2.01		6.96	5.74	3.61
8.1	2.374	2.18	1.80		6.75	5.51	3.40
8.0	2.345	1.95	1.57		6.52	5.28	3.17
7.9	2.315	1.72	1.34		6.29	5.05	2.92
7.8	2.286	1.49			6.06	4.82	2.69
7.7	2.257	1.24			5.81	4.57	2.46
7.6	2.227				5.54	4.32	2.19
7.5	2.198				5.30	4.06	1.93
7.4	2.169				5.02	3.80	1.67
7.3	2.140				4.75	3.53	1.40
7.2	2.110				4.47	3.25	
7.1	2.081				4.19	2.97	
7.0	2.052				3.89	2.67	
6.9	2.022				3.60	2.36	
6.8	1.993				3.27	2.05	
6.7	1.964				2.95	1.73	
6.6	1.934				2.62	1.40	
6.5	1.905				2.28		
6.4	1.876				1.93		
6.3	1.846				1.57		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by FPL

FPL Business HVAC Tables

ERV Rebate Tables

Energy Recovery Ventilator Rebate Table - HVAC Systems							
\$ Per Cfm Air Flow							
Based on AHRI Standard 1060							
AHRI Net Thermal Effectiveness Rating ==>							
AHRI PD Inches	50% to 54%	55% to 59%	60% to 64%	65% to 69%	70% to 74%	75% to 79%	80% or more
\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm
0.1	2.08	2.31	2.54	2.78	3.01	3.24	3.47
0.2	2.04	2.27	2.50	2.73	2.96	3.20	3.43
0.3	2.00	2.23	2.46	2.69	2.92	3.15	3.38
0.4	1.95	2.18	2.42	2.65	2.88	3.11	3.34
0.5	1.91	2.14	2.37	2.60	2.84	3.07	3.30
0.6	1.87	2.10	2.33	2.56	2.79	3.02	3.26
0.7	1.82	2.06	2.29	2.52	2.75	2.98	3.21
0.8	1.78	2.01	2.24	2.47	2.71	2.94	3.17
0.9	1.74	1.97	2.20	2.43	2.66	2.89	3.13
1.0	1.69	1.93	2.16	2.39	2.62	2.85	3.08
1.1	1.65	1.88	2.11	2.35	2.58	2.81	3.04
1.2	1.61	1.84	2.07	2.30	2.53	2.77	3.00
1.3	1.57	1.80	2.03	2.26	2.49	2.72	2.95
1.4	1.52	1.75	1.99	2.22	2.45	2.68	2.91
1.5	1.48	1.71	1.94	2.17	2.41	2.64	2.87
1.6	1.44	1.67	1.90	2.13	2.36	2.59	2.83
1.7	1.39	1.62	1.86	2.09	2.32	2.55	2.78
1.8	1.35	1.58	1.81	2.04	2.28	2.51	2.74
1.9	1.31	1.54	1.77	2.00	2.23	2.46	2.70
2.0	1.26	1.50	1.73	1.96	2.19	2.42	2.65

Notes

1. The AHRI Net Total Thermal Effectiveness for the cooling condition must be 50% or greater to qualify for ERV Rebate
2. The airflow capacity for Rebate calculations shall be the actual exhaust air flow or outside air flow, whichever is least, as specified in the ERV equipment specifications.
3. AHRI's 100% Nominal Airflow capacity will be used for the airflow Rebate calculations if actual air flow exceeds AHRI's listed 100% Nominal Airflow.
4. The Net Total Thermal Effectiveness from AHRI's 75% Airflow Conditions shall be used if ERV equipment actual outside or exhaust air flow specifications are 75% or less of AHRI Nominal Airflow capacity
5. A copy of air flow design submittal for the ERV must be received by FPL prior to Rebate payment processing
6. Rebate Program does not apply to new construction projects that required ERV by code

FPL Business HVAC Tables

FPL Business HVAC Tables

DCV Rebate Tables

Demand Control Ventilation Rebate Table - HVAC Systems

Rebate Retrofit \$500 per Sensor Available for Rebate

Sensors Available for Rebate Not to Exceed Total Installation Cost / 500 (rounded down nearest whole number)

Notes:

1. Demand Control Ventilation (DCV) system must be designed to reduce the outside air flows for a facility at low occupancy, but not to be less than required by all government statutes, codes, ordinances, and accepted engineering practices.
2. The Rebate payment is limited 1 DCV sensor per zone unless approved by FPL Specialist
3. The building's DCV system shall modulate the outside air flow based on air flow measurements and occupancy sensor readings.
4. Occupancy sensors are typically required for each common air conditioned zone and meeting room.
5. The DCV system shall balance the outside air flows with exhaust flows for proper building pressurization at all load and occupancy conditions.
6. Rebate does not apply to new construction projects that required DCV by code.
7. Total installation cost includes sensors, labor, equipment (wiring, dampers,etc), and programming/engineering costs.

FPL Business HVAC Tables

Kitchen Demand Control Ventilation Rebate Table				
Hood Exhaust Air			Rebate Dollars	
0	< CFM ≤	300.00	\$	127
300	< CFM ≤	600.00	\$	381
600	< CFM ≤	900.00	\$	636
900	< CFM ≤	1,200.00	\$	890
1200	< CFM ≤	1,500.00	\$	1,145
1500	< CFM ≤	1,800.00	\$	1,399
1800	< CFM ≤	2,100.00	\$	1,654
2100	< CFM ≤	2,400.00	\$	1,908
2400	< CFM ≤	2,700.00	\$	2,163
2700	< CFM ≤	3,000.00	\$	2,417
3000	< CFM ≤	3,300.00	\$	2,672
3300	< CFM ≤	3,600.00	\$	2,926
3600	< CFM ≤	3,900.00	\$	3,181
3900	< CFM ≤	4,200.00	\$	3,435
4200	< CFM ≤	4,500.00	\$	3,689
4500	< CFM ≤	4,800.00	\$	3,945
4800	< CFM ≤	5,100.00	\$	4,199
5100	< CFM ≤	5,400.00	\$	4,454
5400	< CFM ≤	5,700.00	\$	4,708
5700	< CFM ≤	6,000.00	\$	4,963
Hood Exhaust Air			Rebate Dollars	
6,000	< CFM ≤	7,750	\$	5,832
7,750	< CFM ≤	9,500	\$	7,317
9,500	< CFM ≤	11,250	\$	8,802
11,250	< CFM ≤	13,000	\$	10,286
13,000	< CFM ≤	14,750	\$	11,771
14,750	< CFM ≤	16,500	\$	13,256
16,500	< CFM ≤	18,250	\$	14,739
18,250	< CFM ≤	20,000	\$	16,224
20,000	< CFM ≤	21,750	\$	17,710
21,750	< CFM ≤	23,500	\$	19,195
23,500	< CFM ≤	25,250	\$	20,679
25,250	< CFM ≤	27,000	\$	22,164
27,000	< CFM ≤	28,750	\$	23,649
28,750	< CFM ≤	30,500	\$	25,132
30,500	< CFM ≤	32,250	\$	26,618
32,250	< CFM ≤	34,000	\$	28,103
34,000	< CFM ≤	35,750	\$	29,586
35,750	< CFM ≤	37,500	\$	31,072
37,500	< CFM ≤	39,250	\$	32,557
39,250	< CFM ≤	41,000	\$	34,042
For kitchen DCV a copy of the hood manufacturer specifications listing airflow capacities of the exhaust and make-up air fans must be submitted. When not available a copy of the Test and Balance Report, showing both exhaust and make-up airflows for the fans can be substituted for the hood manufacturer specifications.				

FPL Business HVAC Tables

TES Rebate Tables

TES Rebate Table for A/C Equipment		
Cooling	Customer	
Equipment Type	Rebate	
	per kW Shifted	
New TES Systems	600.00	
Replacement TES Tank(s)	500.00	
Refurbished TES Tank(s)	200.00	
Equipment Type	Constant Speed Path A	Variable Speed Path B
	Rebate Factor	Rebate Factor
Water Cooled Centrifugal	0.66	0.69
	0.66	0.69
	0.66	0.70
	0.71	0.74
	0.71	0.80
Water / Evap Cooled Positive Displacement	0.66	0.69
	0.71	0.73
	0.76	0.78
	0.82	0.85
	0.85	0.88
Air Cooled	1.19	1.24
Calculation Methdology: Rebate Factor From Table X Design Hourly Peak Load (Tons) X \$/KW = Rebate Amount		
Notes:		
Peak hourly KW shifted is based on the design load and is restricted to the seasonal months (June 1-Sept 30) from 3 p.m.-6 p.m. weekdays.		
For sites with multiple equipment sizes and types, a single rebate factor shall be used based on the largest size first, then the highest rebate factor in the thermal storage system.		