





NOTICE OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE
40 CFR §257.95(g)
PLANT SMITH CLOSED ASH POND
FLORIDA POWER & LIGHT COMPANY (FPL)

Arsenic (an Appendix IV constituent) was detected at a statistically significant level (SSL) above its groundwater protection standard at a location MW-13R (a replacement well for MW-13 which was abandoned to allow for closure activities) following the August 2025 assessment monitoring event at Plant Smith Closed Ash Pond. the potential for an ASD for the arsenic SSL at MW-13R is being evaluated. If an ASD is developed, an ASD will be prepared in 2026 for the arsenic SSL and attached to the *2026 Annual Groundwater Monitoring and Corrective Action Report* (submitted in January 2027). If no ASD is developed, an ACM will be initiated for the arsenic SSL in 2026.

FPL will continue groundwater monitoring and reporting activities as required by 40 CFR §257.95.


Billi Jo Huddleston


Date