NOTIFICATION OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE 40 CFR §257.95(g)

GULF CLEAN ENERGY CENTER LANDFILL NO. 1 FLORIDA POWER & LIGHT COMPANY

Cobalt (an Appendix IV constituent) was detected at a statistically significant level (SSL) above its groundwater protection standard at a location (MW-110) during the March and September 2022 assessment monitoring events at Gulf Clean Energy Center Ash Landfill No. 1 (LF1). As documented in the November 14, 2018, notice, a cobalt SSL was previously identified at one other location (MW-104) downgradient of LF1 and an alternate source demonstration for cobalt at LF1 was completed in January 2019.

Florida Power & Light Company will continue groundwater monitoring and reporting activities as required by 40 CFR §257.95.

Benjamin K. Amos, Ph.D.

Date

Shy har

Lane Dorman Da