


NOTICE OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE
40 CFR §257.95(g)
PLANT CRIST GYPSUM STORAGE AREA
GULF POWER COMPANY

Pursuant to 40 CFR §257.95(g), the following Appendix IV constituents were detected at statistically significant levels above the applicable groundwater protection standard during assessment monitoring at Plant Crist Ash Landfill No. 1:

- Cobalt
- Radium 226 and 228 combined

Gulf Power Company will continue groundwater monitoring and reporting activities as required by 40 CFR §257.95.



Lauren Petty, P.G.

Florida Professional Geologist No. 2875

November 14, 2018