

Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report

PLANT NAME: Gulf Clean Energy Center

UNIT: Gypsum Storage Area (GSA)

OWNER/OPERATOR OF FACILITY: Florida Power & Light Company

REPORTING TIMEFRAME: October 19, 2022 to October 19, 2023

PURPOSE: The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report set forth in 40 CFR § 257.80 (c). This report describes the actions taken by Gulf Clean Energy Center to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.

The only activity during the timeframe that had the potential for CCR fugitive dust at the GSA was reclaim for beneficial reuse activity. A dust suppression truck was used to wet the roads in the immediate vicinity of the on-site CCR surface impoundment and was also used when reclaiming CCR for beneficial reuse, as needed. When CCR was transported off-site, enclosed tankers and/or covered trucks were used. Speed limits were posted to reduce vehicle speeds on all roads. Fugitive emissions at Gulf Clean Energy Center are also regulated under the facility's Title V Air Permit.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST CITIZEN COMPLAINTS WITHIN THE REPORTING TIMEFRAME?	Yes	<input data-bbox="1623 232 1686 272" type="checkbox"/> No
---	------------	--

IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)