257.83 (b)(2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT FACILITY NAME: Plant Crist - Gypsum Storage Area				
	OWNER/OPERATOR OF FACILITY: NextEra - Gulf Power				
	INSPECTION DATE: November 19, 2019				
	INSPECTING ENGINEER: Kevin S. Brown, P.E. FL PE 57819				
	Based on the results of my inspection and review of the data provided, it is my professional				
(;)	opinion that the report has been completed in accordance with 40 CFR 257.83(b).				
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING			NO	
	STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? (IF YES, DESCRIBE):				
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION			STRUMENTATION	
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMEN	IAXIMUM RECORDED READING OF FACH INSTRUMENT			
	SINCE PREVIOUS ANNUAL INSPECTION	N/A			
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE				
	IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION*				
	MIN. DEPTH: 0 ft MAX. DEPTH: 11 ft	PRESEN	IT DEPTH: 9 ft		
	MIN. ELEVATION: 36.31 MAX. ELEVATION: 42.31	PRESEN	RESENT ELEVATION: 40.31 ft.		
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. *				
	MIN. DEPTH: 0 ft MAX. DEPTH: 11.0 ft	PRESEN	ESENT DEPTH: 11.0 ft		
	MIN. ELEVATION: 28.3 ft MAX. ELEVATION: 39.3 ft	PRESEN	PRESENT ELEVATION: 39.3 ft.		
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.*		347,305 yd ³		
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND	WATE	WATER: CCR:		
	CCR AT TIME OF INSPECTION*	75,00	0 yd³	204,400 yd ³	
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL				
	STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO			NO	
	ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE				
	THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?				
	(IF YES, DESCRIBE):				
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?		NO		
	(IF YES, DESCRIBE):				

* Depths, elevations and cubic yard volumes are estimates derived by qualified personnel from available information.

Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).

Mon

Kevin S. Brown, P.E.

1/22/2020

Date

